



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

MARIA R. WHYTE
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

April 28, 2016


Mr. David Stout
354 Lakeside Avenue
Angola, NY 14006-9551

Re: Erie County Sewer District No. 2 (ECSD 2), Mini System 4, Town of Evans

Dear Mr. Stout:

Thank you for your letter dated March 30, 2016, concerning surface runoff getting into the ECSD 2 sanitary sewers. In response to your letter, we have checked the manholes at each address you brought to our attention and followed up with the information shown below. For your reference, an inflow protector is an insert that goes beneath the manhole cover and stops the storm water from entering the sanitary sewer system (see picture).

- 1) Opposite House 378 Lakeside in grass near corner of Lakeside & East Lane – *Installed an inflow protector in manhole 204299 (E6932) Work Order (WO) 4053802*
- 2) Opposite House 326, near 333 on tree, on edge of pavement – *Installed an inflow protector in manhole 204301 (E69B1) WO 4053803*
- 3) Opposite House 316, West side of Lakeside runs to this point – *Installed an inflow protector in manhole 204302 (E69B2) WO 4053804*
- 4) Opposite House 274, paved surface runs to this point – *Installed an inflow protector in manhole 204304 (E69B4) WO 4053806*
- 5) Opposite House 9173 (9773 does not exist) in grass, underground pipe cannot take overland flow in storms of quarter inch or more – *Installed an inflow protector in manhole 204305 (E69B5) WO 4053805*
- 6) Two caps on Coolidge in pavement, water runs to them, drainage inlet too high, road not graded properly – *Installed inflow protectors in manholes 204319 (E69C1) WO 4053810 and 204320 (E69C2) WO 4053811*
- 7) Center of Lakeside between 9210 and 9212 Lakeside, road higher than cover – *Installed inflow protectors in manholes 204308 (E69B8) WO 4053808 and 204307 (E69B7) WO 4053809*



Item
6(e)

- 8) Near Center of Lakeside at West Lane, water runs to this cap, re-grade pavement – *Already has an inflow protector installed in manhole 204309 (E69B9), no action was required.*
- 9) Opposite 9255 East side in gravel at Lakeside and Berrywood/West Lane, low spot takes upland flow – *Installed an inflow protector in manhole 204310 (E69BA) WO 4053807*
- 10) Near junction at Woodside – *Already has an inflow protector installed in manhole 204298 (E6931), no action was required.*
- 11) Near junction on Lake Breeze – *Already has an inflow protector installed in manhole 204328 (E692F), no action was required.*

Should you have any additional questions or concerns, please do not hesitate to contact me at (716) 549-3161.

Sincerely,



Carl D. Horne
Sewer District Manager

Cc: A. Horton (ECSD 2 Board of Managers)
J. Fiegl / D. Millar / M. Salah / 2.2.2.I&I
G. Absolom
R. Rehac

V:\Sewerage Management\file\District SR\Response Letter MS4 4-28-16.docx

2016.04.28 15:10
F 10:10



Eden Corn Festival, inc.

P.O. Box 86
Eden, New York 14057
www.edencornfest.com

Angela Horton, P.E.
Secretary to the Board of Directors
Erie County Sewer District 2
95 Franklin Street, Room 1073
Buffalo, NY 14202

June 6th 2016

Dear Angela Horton, P.E.

The Eden Corn Festival Inc. Is petitioning the Erie County Sewer District 2 for supplies for the installation of a sewer line in the Eden Corn Festival's vendor camping and storage area.

Supplies being petitioned include: 980 feet of pipe, 12 T's, and 2 caps. Grey water holding tanks have been utilized in previous years which is causing a financial hardship to the Festival. The installation of a permanent sewer line would be a tremendous benefit to the Eden Corn festival as well as the 20 Not-For-Profit Groups it supports.

The Eden Corn Festival is located on the grounds of the American Legion Post #880, 2912 Legion Drive, Eden, NY. The Festival supports 20 Not-For-Profit organizations and raises approximately \$300,000 annually for these groups.

Thank you for considering our request and we look forward to hearing back from you. If additional information is needed please feel free to contact me via phone, email, or US Mail.

Kind Regards

Jeff Winter
President
Eden Corn Festival Inc.
P.O. Box 86
Eden, New York 14057
(716)-432-3191
jmwinter4@gmail.com

5014 74 - 3 7/11/25

Item
6(h)