COUNTY OF ERIE
DEPARTMENT OF ENVIRONMENT AND PLANNING
DIVISION OF SEWERAGE MANAGEMENT

• • MEMORANDUM • •

TO: JAMES A. CARR, P.E., Secretary, ECSD 6 Board of Managers

FROM: ANGELA M. HORTON, P.E., Coordinator of Sewer Construction Projects

DATE: November 26, 2014

SUBJECT: ECSD 6 Board of Managers – Approval for Compliance Hearing

---

Please present at your next Board of Managers meeting the attached list of property owners that have not corrected a violation found during their house inspection and require a Compliance Hearing.

The Division of Sewerage Management is recommending a Compliance Hearing for the attached list. Should you have any questions, please contact me at 858-8437 or *angela.horton@erie.gov*.

MOVED BY: _____

SECONDED BY: _____

APPROVED/DISAPPROVED: _____

DATE: _____

_____
James A. Carr, P.E.
SECRETARY

Encl.
cc: 6.2.2.I&I
V:\Sewerage Management\I&I Program\House Inspection Program\BOMtemplateD6.doc

Item 4(b)

COUNTY OF ERIE

MARK C. POLONCARZ
COUNTY EXECUTIVE

MARIA R. WHYTE
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

October 21, 2014

[redacted]

Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 6, Mini System 5
For Property Located at: **3092 SOUTH PARK AVE**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 3/11/2014, 6/13/2014, and 9/17/2014, that the above mentioned property was inspected on 10/3/2012, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

DISCONNECT MIDDLE SUMP PUMP FROM THE SANITARY SEWER

As a result of your failure to comply with these notifications, your name has been referred to the ECSD 6 Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed by that time, the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to $500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari Sr.
Sewer District Manager

cc: ECSD 6 Board of Managers
A. Horton / 6.2.2.I&I

SECTION 305 – Footing Drains, Roof Drains and Sump Pumps:
"...roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer."

SECTION 501 – Prohibited Discharges:
"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at *www.erie.gov/dsm.*

CENTRAL REGION • ERIE COUNTY SEWER DISTRICT NOS. 3, 6 & 8 • S-3690 LAKE SHORE ROAD • BUFFALO, NY 14219
(716) 823-8188 • FAX: (716) 823-1635 • WWW.ERIE.GOV

COUNTY OF ERIE

MARK C. POLONCARZ
COUNTY EXECUTIVE

MARIA R. WHYTE
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

October 21, 2014

[redacted]

Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 6, Mini System 5
For Property Located at: **88 VEREL AVE**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 3/11/2014, 6/13/2014, and 9/17/2014, that the above mentioned property was inspected on 5/13/2013, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

DISCONNECT DOWNSPOUTS FROM THE SANITARY SEWER

As a result of your failure to comply with these notifications, your name has been referred to the ECSD 6 Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed by that time, the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to $500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari Sr.
Sewer District Manager

cc: ECSD 6 Board of Managers
A. Horton / 6.2.2.I&I

SECTION 305 – Footing Drains, Roof Drains and Sump Pumps:
"...roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer."

SECTION 501 – Prohibited Discharges:
"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at *www.erie.gov/dsm.*