

COUNTY OF ERIE
DEPARTMENT OF ENVIRONMENT AND PLANNING
DIVISION OF SEWERAGE MANAGEMENT

• • MEMORANDUM • •

TO: DAVID C. MILLAR, P.E., Secretary, ECSD 3 Board of Managers
FROM: ~~DAVID C. MILLAR~~ ANGELA M. HORTON, P.E., Coordinator of Sewer Construction Projects
DATE: June 6, 2016
SUBJECT: ECSD 3 Board of Managers – Approval for Enforcement Hearing

Please present at your next Board of Managers meeting the attached list of property owners that are in one of the following categories and require an Enforcement Hearing:

- 1) Have not completed a house inspection.
- 2) Have not corrected a violation found during their house inspection.

The Division of Sewerage Management is recommending an Enforcement Hearing for the attached list. Should you have any questions, please contact me at 858-8437 or angela.horton@erie.gov.

MOVED BY: _____

SECONDED BY: _____

APPROVED/DISAPPROVED: _____

DATE: _____

David C. Millar, P.E.
SECRETARY

Encl.
cc: 3.2.2.1&I

Item
5(c)



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

June 8, 2016

[REDACTED]

Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 19
For Property Located at: **5301 ELECTRIC AVE - Right**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/28/2016, and 4/28/2016, that the above mentioned property was inspected on 8/13/2014, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

REPLACE PERFORATED CAP WITH MUSHROOM CAP; REPLACE SOLID CAP WITH MUSHROOM CAP; REPAIR BROKEN OR LOOSE RISER PIPE FROM VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Footing Drains, Roof Drains and Sump Pumps:

"...roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer."

SECTION 501 - Prohibited Discharges:

"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water."

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm.



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

June 8, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: 4947 MORGAN PKWY

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 7/30/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

RAISE LOW LYING VENT 6 INCHES ABOVE GRADE AND INSTALL A MUSHROOM CAP

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Footing Drains, Roof Drains and Sump Pumps:
"...roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer."

SECTION 501 - Prohibited Discharges:
"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water."

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm.



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 31, 2016



Re: **FINAL INSPECTION NOTICE**
Erie County Sewer District No. 3, Mini System 19
Property inspection required at: **5283 WOOD AVE**

Dear Property Owner:

Our records indicate that we have notified you on three separate occasions: 3/18/2015, 6/4/2015, and 4/28/2016, that it was necessary for you to schedule an inspection of the above noted property in order to comply with Section 1001 of the "Rules and Regulations For Erie County Sewer Districts" www.erie.gov/dsm-R&R.

As a result of your failure to comply with these notifications, your name has been referred to the Erie County Sewer District No. 3 Board of Managers for consideration of holding a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the non compliance continues.

Should you have any questions on this matter, or wish to schedule an inspection, please contact our office at (716) 823-8188, during normal business hours, Monday through Friday 8 am to 4 pm.

Sincerely,

Steven J. Canestrari Sr.
Sewer District Manager

cc: ECSD 3 Board of Managers
A. Horton / 3.2.2.1&I

SECTION 1001 – Powers and Authority of Inspectors: "Authorized representatives of the District, bearing proper identification, shall be permitted to enter all properties in the District and contracting areas which are served by a sanitary sewer for the purpose of inspection, observation, records examination and copying, measurement, sampling and testing...in accordance with the provisions of these Rules and Regulations."



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 17, 2016



Re: **FINAL INSPECTION NOTICE**
Erie County Sewer District No. 3, Mini System 29
Property inspection required at: **4987 MT VERNON BLVD**

Dear Property Owner:

Our records indicate that we have notified you on three separate occasions: 10/16/2015, 3/7/2016, and 4/7/2016, that it was necessary for you to schedule an inspection of the above noted property in order to comply with Section 1001 of the "Rules and Regulations For Erie County Sewer Districts" www.erie.gov/dsm-R&R.

As a result of your failure to comply with these notifications, your name has been referred to the Erie County Sewer District No. 3 Board of Managers for consideration of holding a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the non compliance continues.

Should you have any questions on this matter, or wish to schedule an inspection, please contact our office at (716) 823-8188, during normal business hours, Monday through Friday 8 am to 4 pm.

Sincerely,

Steven J. Canestrari Sr.
Sewer District Manager

cc: ECSD 3 Board of Managers
A. Horton / 3.2.2.I&I

SECTION 1001 - Powers and Authority of Inspectors. "Authorized representatives of the District, bearing proper identification, shall be permitted to enter all properties in the District and contacting areas which are served by a sanitary sewer for the purpose of inspection, observation, records examination and copying, measurement, sampling and testing, in accordance with the provisions of these Rules and Regulations."



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 19
For Property Located at: **5070 BRADLEY LN**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 11/2/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 11/28/2014, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

LOCATE AND RAISE (BURIED) VENT 6 INCHES ABOVE GRADE AND INSTALL A MUSHROOM CAP

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.1&1

SECTION 305 - Leaking Drains, Roof Drains and Sump Pumps.

Roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges.

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System. a. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 19
For Property Located at: **3985 JEFFERSON AVE**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 7/11/2014, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

INSTALL MUSHROOM CAP ON VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Footing Drains, Roof Drains and Sump Pumps:

Foot drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges:

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 19
For Property Located at: **4013 PARK AVE**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 12/4/2014, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

LOCATE AND RAISE (BURIED) VENT 6 INCHES ABOVE GRADE AND INSTALL A MUSHROOM CAP

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - *Locating Drains, Roof Drains and Sump Pumps:*

Roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - *Prohibited Discharges:*

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at [a website provided](http://www.erie.gov/dsm)



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 19
For Property Located at: **5062 BRADLEY LN**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 11/24/2014, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

REPLACE PERFORATED CAP WITH MUSHROOM CAP ON VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Floating Drains, Roof Drains and Sump Pumps.

Roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges.

The following substances and wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/isa



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 19
For Property Located at: **5074 CLARICE DR**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 7/31/2014, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

REPLACE PERFORATED CAP WITH MUSHROOM CAP ON VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Floating Drains, Root Drains and Sump Pumps:

roof drains, sump pumps, or other drains discharging surface runoff and water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges:

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or roofing water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



Scheduled for
a reinspection
6/8/16

COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **4923 MORGAN PKWY**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 7/1/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

RAISE LOW LYING VENT 6 INCHES ABOVE GRADE AND INSTALL A MUSHROOM CAP

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.1&1

SECTION 305 - Floating Drains, Roof Drains and Sump Pumps.
Roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges.
The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 4. Surface runoff, ground water, roof runoff, sump pump discharge, substance drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **4954 MORGAN PKWY**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 11/2/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 10/16/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

REPAIR BROKEN RISER PIPE FROM VENT AND INSTALL 4 INCH MUSHROOM CAP. DISCONNECT SUMP PUMP FROM SANITARY SEWER.

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A Horton / 3 2.2.I&I

SECTION 305 - Leaking Drains, Roof Drains and Sump Pumps:

Roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges:

The following substances and waste waters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof run-off, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **4996 MORGAN PKWY**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 11/2/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 10/21/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

INSTALL 4 INCH MUSHROOM CAP ON VENT CLOSE TO HOUSE. INSTALL 4 INCH SOLID CAP ON VENT AWAY FROM HOUSE.

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Floating Drains, Roof Drains and Sump Pumps.

Roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges.

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/ds3



COUNTY OF ERIE

MARK C. POLONCARZ


COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **4542 LAKESHORE RD**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 8/24/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 8/7/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

DISCONNECT SUMP PUMP FROM SANITARY SEWER AND REPLACE SOLID CAP WITH MUSHROOM CAP ON VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Leaking Drains, Roof Drains and Sump Pumps:

roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges:

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/efdm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **4582 MORGAN PKWY**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 9/30/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 9/3/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

DISCONNECT SUMP PUMP FROM SANITARY SEWER. REPAIR BROKEN RISER PIPE FROM VENT AND RAISE 6 INCHES ABOVE GRADE AND INSTALL A MUSHROOM CAP

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Leaking Drains, Roof Drains and Sump Pumps:
"roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer."

SECTION 501 - Prohibited Discharges:
"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water."

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **4680 MORGAN PKWY**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 11/2/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 10/19/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

RAISE LOW LYING VENT 6 INCHES ABOVE GRADE AND RE-INSTALL A MUSHROOM CAP

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Ganestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Footing Drains, Roof Drains and Sump Pumps:

... roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer

SECTION 501 - Prohibited Discharges:

"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3, Mini System 12
For Property Located at: **3022 WALBRIDGE DR**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 11/2/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 10/23/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

REPLACE PERFORATED CAP WITH MUSHROOM CAP ON VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Floating Drains, Roof Drains and Sump Pumps.

roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer.

SECTION 501 - Prohibited Discharges.

The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: 1. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water.

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



scheduled for
a reinspection
6/8/16

COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 20, 2016



Re: **FINAL VIOLATION NOTICE**
Erie County Sewer District No. 3. Mini System 12
For Property Located at: **4845 KENNISON PKWY**

Dear Property Owner,

A recent review of our records indicate that you were advised by letters dated 11/2/2015, 3/7/2016, and 4/7/2016, that the above mentioned property was inspected on 10/27/2015, and the following apparent violation of Section 305 and/or 501 of the "RULES AND REGULATIONS FOR ERIE COUNTY SEWER DISTRICTS" was observed:

REPLACE PERFORATED CAP WITH MUSHROOM CAP ON VENT

As a result of your failure to comply with these notifications, your name has been referred to the Board of Managers for consideration of requesting a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the violation continues.

Should you have any questions on this matter, or wish to schedule a reinspection, please feel free to contact me at (716) 823-8188 during normal business hours, Monday through Friday 8 am to 4 pm.

Very truly yours,

Steven J. Canestrari
Sewer District Manager

cc: Board of Managers
A. Horton / 3.2.2.I&I

SECTION 305 - Floating Drains, Roof Drains and Sump Pumps:

"... roof drains, sump pumps, or other drains discharging surface runoff or ground water shall not be connected to the sanitary sewer."

SECTION 501 - Prohibited Discharges:

"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System - k Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water."

The Rules and Regulations for Erie County Sewer Districts can be viewed at www.erie.gov/dsm



COUNTY OF ERIE

MARK C. POLONCARZ

COUNTY EXECUTIVE

THOMAS R. HERSEY, JR.
COMMISSIONER

DEPARTMENT OF ENVIRONMENT & PLANNING

JOSEPH L. FIEGL, P.E.
DEPUTY COMMISSIONER

May 17, 2016

[REDACTED]

Re: **FINAL INSPECTION NOTICE**
Erie County Sewer District No. 3, Mini System 29
Property inspection required at: **4969 MT VERNON BLVD**

Dear Property Owner:

Our records indicate that we have notified you on three separate occasions: 10/16/2015, 3/7/2016, and 4/7/2016, that it was necessary for you to schedule an inspection of the above noted property in order to comply with Section 1001 of the "Rules and Regulations For Erie County Sewer Districts" www.erie.gov/dsm-R&R.

As a result of your failure to comply with these notifications, your name has been referred to the Erie County Sewer District No. 3 Board of Managers for consideration of holding a hearing to obtain compliance with this request.

This matter is scheduled to be taken up at the next meeting of the Board of Managers. If compliance with this request is not completed the Board of Managers will consider scheduling a hearing on the matter, the result of which could be fines of up to \$500.00 per day that the non compliance continues.

Should you have any questions on this matter, or wish to schedule an inspection, please contact our office at (716) 823-8188, during normal business hours, Monday through Friday 8 am to 4 pm.

Sincerely,

Steven J. Canestrari Sr.
Sewer District Manager

cc: ECSD 3 Board of Managers
A. Horton / 3.2.2.I&I

SECTION 1001 - Powers and Authority of Inspectors: "Authorized representatives of the District, bearing proper identification, shall be permitted to enter all properties in the District and contracting areas which are served by a sanitary sewer for the purpose of inspection, observation, records examination and copying, measurement, sampling and testing...in accordance with the provisions of these Rules and Regulations."