

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
JANUARY 2016 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTAL	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	95	164	54
Stakeouts	51	69	17
TOTAL STAKEOUTS	137		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	10,876	785	0	11,661

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	0	616	0	616
By District				0

	D1	D4	D5	TOTAL
House Inspections		9		9
Reinspections		10		10
Violations		2		2
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	1	0	0	1

Root Treatment (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	0	616	0	616
Mechanically Cleaned				0

Sewerline Repairs	D1	D4	D5	TOTAL

CONSTRUCTION		
Mainline	Subdivisions	Commercial
FAIRWAYS @ LANCASTER	HARRIS HILL COMMOMS	UPSTATE REBAR-PUNCHLIST
THE BELVEDERE		

Plans Reviewed:	D1	D4	D5	TOTAL

Item (6/2)

ERIE COUNTY - SEWER DISTRICTS 1,4,5
01/01/2016 TO 02/01/2016
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	1	9	2	12
Taps	1	2	0	3
Disconnect	0	1	2	3
Repair	4	12	0	16
TOTAL	6	24	4	34

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	1	0	1
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	2	10	2	14
Exist Residential (ER)	0	0	0	0
TOTAL	2	11	2	15

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	1	0	1
Exist Commercial Issued (EC)	0	1	1	2
New Residential Issued (NR)	3	6	2	11
Exist Residential Issued (ER)	2	13	1	16
TOTAL	5	21	4	30

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 1276	\$ 0	\$ 1276
Exist Commercial Fees (EC)	\$ 0	\$ 2	\$ 2	\$ 4
New Residential Fees (NR)	\$ 6	\$ 3012	\$ 504	\$ 3522
Exist Resident Fees (ER)	\$ 4	\$ 26	\$ 2	\$ 32
TOTAL	\$ 10	\$ 4316	\$ 508	\$ 4834

**DISTRICT #1
CONNECTIONS & REPAIRS**

Date Connected	Permit Number	Address	Town	Type of Connection
1/5/2016	CP0103748	137 Whitney 102 Mayberry Dr.	Cheektowaga	Repair
1/6/2016	CP0104723	West	Cheektowaga	Repair
1/14/2016	CP0104336	42 Maria	Cheektowaga	Repair
1/25/2016	CP0111652	176 Messer	Cheektowaga	Tap
1/28/2016	CPC0111657	105 Blossomwood	Cheektowaga	Wye
1/28/2016	CP0101986	1475 Borden	Cheektowaga	Repair

DISTRICT #4

Date Connected	Permit Number	Address	Town	Type of Connection
1/5/2016	CP0408371	41 Pear Tree	Lancaster (T)	Wye
1/5/2016	CP0408412	208 Iroquois	Lancaster (T)	Repair
1/7/2015	CP0408389	5828 Broadway (Bldg 400)	Lancaster (T)	Wye
1/7/2016	CP0408416	46 Oxford	Lancaster (V)	Repair
1/7/2016	CP0408362	20 Middlebury	Lancaster (T)	Wye
1/7/2016	CP0408415	48 Freeman	Lancaster (T)	Disconnect
1/8/2016	CP0408370	694 Pleasant View	Lancaster (T)	Wye
1/8/2016	CP0407400	27 Glendale	Lancaster (T)	Repair
1/11/2016	CP0408383	27 Middlebury	Lancaster (T)	Wye
1/11/2016	CP0408421	219 Broezel	Lancaster (T)	Repair
1/12/2016	CP0408420	258 Broezel	Lancaster (T)	Repair
1/13/2016	CP0408392	20 Jonquille	Lancaster (T)	Wye
1/13/2016	CO0408418	345 Seneca	Lancaster (T)	Repair
1/14/2016	CP0408382	6 Jonquille	Lancaster (T)	Wye
1/14/2016	CP0408422	4845 Transit Rd "F"	Lancaster (T)	Repair
1/15/2016	CP0408419	236 Seneca	Lancaster (T)	Repair
1/1/2016	CPC0408411	3981 Walden	Lancaster (T)	Tap
1/19/2016	CPC0408417	148 Seneca	Lancaster (T)	Repair
1/19/2016	CP0408425	2 Charlton	Lancaster (V)	Repair
1/20/2016	CPC0408426	56 Eastwood Pkwy	Lancaster (T)	Repair
1/21/2016	CPC0408352	34 Ann Marie	Lancaster (T)	Tap
1/26/2016	CP0408384	21 Middlebury	Lancaster (T)	Wye
1/26/2016	CP0408369	42 Middlebury	Lancaster (T)	Wye
1/29/2016	CP0408431	43 Harvey	Lancaster (V)	Repair

DISTRICT #5

Date Connected	Permit Number	Address	Town	Type of Connection
1/5/2016	CPC0503341	8320 Clarence Center	Clarence	Wye
1/8/2016	CP0503344	6805 Rivera Way	Clarence	Wye
1/13/2016	CPC0500784	5175 Transit	Clarence	Disconnect
1/13/2016	CPC0500784	5181 Transit	Clarence	Disconnect

**TOWN OF CLARENCE
DISTRICTS 2,6**

District #	Street Address	Date	Type	Permit Issued By:
2	9285 Kristina Circle	1/4/2016	WYE	Town Of Clarence
6	5644 Chatham	1/27/2016	WYE	Town Of Clarence
6	5690 Waterford	1/27/2016	WYE	Town Of Clarence

January 2016 Maintenance

District 1

Borden

Painted pumps, valves and piping.

Cayuga

Started up heating boiler.

Empire Drive

Installed manhole level alarm system.

Woodlands

Removed blockage from pump 2.

District 4

Aurora North

Repaired pump alternator.

Broadway

Completed physical installation of new VFD.

Installed new speed command signal isolator in level control cabinet.

Depew ORF

Repaired hypo building ventilation louvers.

Hall

Replaced pump failure alarm relays.

Haskell

Painted drywell walls, floor and equipment.

Pleasantview

Painted drywell walls, floor and equipment.

Vanderbilt

Removed wetwell dewatering pumps for rebuild.

District 4 Offices/Garages

Cleaned all heat pump glycol sediment screens.

Checked HVAC air filters, replaced as needed.

District 5

Clarence Research

Replacement of the lab/equipment building nearing completion.

Eastern Hills

Added power monitor generator transfer switch.

Pine Breeze

Installed new phase monitor in power transfer switch.

Transit Valley

Freed and lubricated generator air intake louvers.

General Maintenance

All stations were inspected weekly.

Snow removal was performed at all facilities as needed.

Preventive maintenance was performed on all pump station comminutors.

2016 January UFPO Numbers

(By District/Region)

Total UFPO Tickets:	810
Tickets Outside ECSD Boundary:	72

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	95	51	44	12%	12%
District 4	164	69	95	20%	26%
District 5	54	17	37	7%	10%
Total NR	313	137	176	39%	49%

District 3	270	160	107	33%	30%
District 6	25	12	13	3%	4%
District 8	15	11	4	2%	1%
Total CR	310	183	124	38%	34%

District 2	115	53	62	14%	17%
Total SR	115	53	62	14%	17%

Totals:	738	373	362
----------------	-----	-----	-----

Late Tickets

NR	CR	SR
0	0	0

NR COMPLAINT SUMMARY-JANUARY 2016

DISTRICT 1

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10054094		01/02/2016	SEWER BACKUP-65 HILLPINE RD	HOMEOWNER'S PROBLEM	E-S-N01-C-003
10054375		01/19/2016	ODOR COMPLAINT-25 ELMLEAF	HOMEOWNER'S PROBLEM	E-S-N01-C-003
10054321		01/12/2016	SIDEWALK CRACKING-204 LOSSON	HOMEOWNER'S PROBLEM	E-S-N01-C-003-SL
10055166	4051462	01/26/2016	SEWER BACKUP-59 CANNAS	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-005-SL

DISTRICT 4

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10054147		01/07/2016	WATER IN BASEMENT - 6 CHARLTON PL	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10055045		01/22/2016	WATER IN BASEMENT - 49 CHARLTON	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10054373	4050689	01/18/2016	SEWER BACKUP-25 IMPALA	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-005-SL
10054392		01/18/2016	SEWER BACKUP-20 GARFIELD	HOMEOWNER'S PROBLEM	E-S-N04-C-009

DISTRICT 5

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10055154		01/27/2016	BACK UP 4830 WEST AVE.	HOMEOWNER'S PROBLEM	E-S-N05-C-009

NR I & I SUMMARY - JANUARY 2016

DISTRICT 1

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text
4050501	01/06/2016	INSTALL MANHOLE MONITOR - EMPIRE DR.	RAISED MANHOLE(4)	E-S-N01-C-009-MH	BAF1E

NR MECHANICAL CLEANING - JANUARY 2016

DISTRICT 4

Order	Malfunc.end	Description	Act. code text	Functional Loc.	Activity text	Quant.factor
4050687	01/19/2016	TELEWISE/ROOTCUT - IMPALA	MECHANICAL ROOT CUT	E-S-N04-C-005-SL	F29ED	169

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
FEBRUARY 2016 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTAL	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	95	133	120
Stakeouts	50	69	61
TOTAL STAKEOUTS	180		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	14,905	269	296	15,470

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	4,310	0	0	4,310
By District				0

	D1	D4	D5	TOTAL
House Inspections	1	1		2
Reinspections				0
Violations	1	1		2
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	1	0	0	1

Root Treatment (ft)	D1	D4	D5	TOTAL
Vapor Rooting				0
Cutting w/ Flusher	2,436	0	0	2,436
Mechanical Cleaning				0

Sewerline Repairs	
--------------------------	--

SSO's	District #1 3270 Clinton Street West Seneca 2/24/16
--------------	---

CONSTRUCTION		
Mainline	Subdivisions	Commercial
FAIRWAYS @ LANCASTER	HARRIS HILL COMMONS	UPSTATE REBAR-PUNCHLIST
THE BELVEDERE	CENTRAL SQUARE VILLAS (FINAL)	

Plans Reviewed:	EASTGATE PLAZA - D5
	6449 TRANSIT RD. - D5

ERIE COUNTY - SEWER DISTRICTS 1,4,5
2/1/2016 TO 2/29/2016
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	7	0	7
Taps	1	2	0	3
Disconnect	0	0	0	0
Repair	3	6	1	10
TOTAL	4	15	1	20

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	1	0	1
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	1	8	0	9
Exist Residential (ER)	0	0	0	0
TOTAL	1	9	0	10

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	1	0	0	1
New Residential Issued (NR)	3	15	0	18
Exist Residential Issued (ER)	1	7	1	9
TOTAL	5	22	1	28

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 0	\$ 0	\$ 0
Exist Commercial Fees (EC)	\$ 2	\$ 0	\$ 0	\$ 2
New Residential Fees (NR)	\$ 1006	\$ 8980	\$ 0	\$ 9986
Exist Resident Fees (ER)	\$ 2	\$ 14	\$ 2	\$ 18
TOTAL	\$ 1010	\$ 8994	\$ 2	\$ 10006

Date Connected	Building_	Building_Stre	Building_Town	Code	Type	Permit_Type
2/1/2016 13:15	10	Middlebury	Lancaster	N	S	Connection
2/2/2016 13:15	38	Pear Tree Ln	Lancaster	N	S	Connection
2/3/2016 13:15	36	Pear Tree Ln	Lancaster	N	S	Connection
2/4/2016 13:15	9	Crabapple Lar	Lancaster	N	S	Connection
2/5/2016 13:30	20	Logan Lane	Lancaster	N	S	Connection
2/10/2016 14:30	5123	Transit Rd	Lancaster	N	C	Connection
2/22/2016 11:30	53	Tranquility Tr	Lancaster	N	S	Connection
2/22/2016 11:45	60	Tranquility Tr	Lancaster	N	S	Connection
2/23/2016 10:00	4	Homewood A	Cheektowaga	N	S	Connection
2/26/2016 13:15	46	Middlebury	Lancaster	N	S	Connection
2/29/2016 10:45	6	Bennington L	Lancaster	N	S	Connection

2016 February UFPO Numbers

(By District/Region)

Total UFPO Tickets:	736
Tickets Outside ECSD Boundary	51

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	95	45	50	13%	15%
District 4	133	62	69	18%	21%
District 5	120	59	61	16%	19%
Total NR	348	166	180	47%	56%

District 3	188	117	70	26%	22%
District 6	46	23	19	6%	6%
District 8	19	14	5	3%	2%
Total CR	253	154	94	34%	29%

District 2	84	31	49	11%	15%
Total SR	84	31	49	11%	15%

Totals:	685	351	323
----------------	-----	-----	-----

Late Tickets

NR	CR	SR
1	2	0

DISTRICT #1 CONNECTIONS & INSPECTIONS

Date Connected	Permit Number	Address	Town	Code N or E	Type S, C, M, or T	Contractor	Type of Connection
2/1/2016	CP0103546	125 Denise	Cheektowaga	E	S	G&K - Lateral Rehab	Repair
2/5/2016	CP0111659	54 Ransier	West Seneca	E	C	Union Concrete	Repair
2/9/2016	CP0103738	113 Whitney	Cheektowaga	E	S	Cellino Plumbing	Repair
2/23/2016	CP0111661	4 Homewood Av	Cheektowaga	N	S	Schuster Constr/Alps Plmbg	Tap

DISTRICT #4 CONENCTIONS & INSPECTIONS

Date Connected	Permit Number	Address	Town	Code N or E	Type S, C, M, or T	Contractor	Type of Connection
2/1/2016	CP0408403	10 Middlebury	Lancaster (T)	N	S	ECI	Wye
2/2/2016	CP0408398	38 Pear Tree	Lancaster (T)	N	S	ECI	Wye
2/3/2016	CP0408399	36 Pear Tree	Lancaster (T)	N	S	ECI	Wye
2/4/2016	CP0408402	9 Crabapple	Lancaster (T)	N	S	ECI	Wye
2/5/2016	CP0408328	20 Logan	Lancaster (T)	N	S	Gary Adamczyk Mulvey Constr/Thomann	Wye
2/9/2016	CP0408427	5123 Transit	Lancaster (T) Depew/Chktg	N	C	Asphalt	Tap
2/10/2016	CP0408432	48 King 21 Oakwood	(V)	E	S	RIC Plumbing	Repair
2/11/2016	CP0404055	Common	Lancaster (T)	E	S	Pipeworks Plumbing	Repair
2/11/2016	CP0408434	40 Colonial	Lancaster (V)	E	S	Cellino Plumbing	Repair
2/22/2016	CP0408424	53 Tranquility	Lancaster (T)	N	S	G&K	Wye
2/22/2016	CP0408407	60 Tranquility 62 Running	Lancaster (T)	N	S	G&K	Tap
2/23/2016	CP0403030	Brook Dr	Lancaster (T)	E	S	Superior Plumbing	Repair
2/23/2016	CP0408446	55 4th Av	Lancaster (V) Depew/Lanc	E	S	Roto Rooter	Repair
2/25/2016	CP0408447	102 Argus	(V)	E	S	Roy's Plumbing	Repair
2/26/2016	CP0408405	46 Middlebury	Lancaster (T)	N	S	ECI	Wye
2/29/2016	CP0408408	6 Bennington	Lancaster (T)	N	S	ECI	Wye

DISTRICT #5 CONNECTIONS & INSPECTIONS

Date Connected	Permit Number	Address	Town	Code N or E	Type S, C, M or T	Contractor	Inspector	Type of Connection
2/26/2016	CP0501561	6477 Poplar Ct	Clarence	E	S	Roy's Plumbing	P. Faragiano	Repair

CLARENCE TOWN DISTRICT #4

Town of Clarence

February

District

#	Street Address	Date	Contractor	Inspector	Type	Permit Issued By:
4	5372 Glenview	2/4/2016	Gary Adamczyk	P. Faragiano	WYE	Town of Clarence
4	9687 Golden Aster	2/12/2016	Gary Adamczyk	P. Faragiano	WYE	Town of Clarence

February 2016 Maintenance

District 1

Cayuga

Removed all equipment that was replaced during the recent VFD/Controls upgrade for recycling.

Lubricated pumps and drive u-joints and bearings.

Began repair of ORF chamber 2 drain valve.

Inspected and cleaned force main AVR valves.

Cleaned influent bar screens.

Performed PM on comminutors

Empire Drive

Adjusted alarm levels on manhole level monitor.

Changed cellular data provider for improved signal reception and reliability.

Industrial Park

Removed all equipment that was replaced during the recent VFD/Controls upgrade for recycling.

Lubricated pumps and driveshaft u-joints and bearings.

Cleaned influent bar screens.

Woodlands

Replaced level control float switch.

District 4

Bowmansville

Removed blockage from pump #1.

Cleaned influent bar screens.

Broadway

Continuing the upgrade of motor drives and controls.

Removed all old equipment for recycling.

Repaired sidewall exhaust fan.

Depew

Removed all equipment that was replaced during the recent VFD replacements for recycling.

Lubricated pumps and driveshaft bearings.

Removed frozen wash tank potable water fill valve for replacement.

Inspected all pump casing wear rings.

Installed new manual drive screw on rotary check valve #2.

Performed PM on comminutors.

Began disassembly and repair of spare pump rotating assembly.

Cleaned influent bar screens.

Depew ORF

E.C. Prison Comminutor

Removed blockage and reset comminutor.

Hall

Replaced level control float switch.

Haskell

Removed blockage from pump 1 volute.

Iroquois

Cleaned influent bar screens.

Warner

Reset VFD after failure.

Cleaned influent bar screens.

District 4 Offices/Garages

Performed scheduled HVAC maintenance al all heat pumps.

Repaired main office heat pump.

Began repair of south garage unit heater.

Re-lamped (4) light fixtures in Offices and garages.

District 5

Bryant

Repaired intermittent pump fail alarm.

Clarence Research

Installed emergency generator connectors and tested generator and power transfer switch.

Replaced (2) defective float switches in EQ tank.

Loch Leaz

Replaced level control float switch.

Transit Valley

General Maintenance

All stations were inspected weekly.

Snow/ice removal was performed at all facilities as needed.

Began annual inspection and PM on all emergency generators.

NR COMPLAINT SUMMARY - FEBRUARY 2016

DISTRICT 1

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10056392		02/25/2016	SEWER BACK-UP 19 JEROME CT	HOMEOWNER'S PROBLEM	E-S-N01-C-002
10055709		02/24/2016	SEWER BACKUP-82 FAIRELM LN	REFERRED TO OTHERS	E-S-N01-C
10056320		02/20/2016	MANHOLE ISSUE-60 EMPIRE DR AT CLINTON ST	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-009
10056322		02/20/2016	SEWER BACK-UP-131 N SEINE DR	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10056331		02/20/2016	SEWER BACKUP-601 SENECA CREEK RD	HOMEOWNER'S PROBLEM	E-S-N01-C-010
10056372		02/24/2016	SEWER BACKUP-76 DEER CHASE RD	HOMEOWNER'S PROBLEM	E-S-N01-C-010
10056356		02/24/2016	SEWER BACKUP 114 FAIRELM	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-001
10056318		02/24/2016	BACK UP-171 VERN	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-001
10056329		02/20/2016	SEWER BACKUP-171 VERN LN	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-001
10056408	4052717	02/28/2016	SEWER BACKUP-1356 LOSSON RD	REFERRED TO OTHERS	E-S-N01-C-004
10055217		02/02/2016	MANHOLE COVER TIPPED-136-140 S SEINE	REFERRED TO OTHERS	E-S-N01-C-005
10056301		02/22/2016	SEWER BACKUP 54 YVETTE	HOMEOWNER'S PROBLEM	E-S-N01-C-006
10055174		02/03/2016	BACK UP-41 PHEASANT LANE	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10055648		02/14/2016	SEWER BACKUP-5 FLORETTE DR	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10055673		02/17/2016	SEWER BACKUP 56 SOUTH PRINCE	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10056355		02/24/2016	SEWER BACKUP 34 GARY LN	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-007
10055666		02/18/2016	BACKUP-2150 UNION RD.	HOMEOWNER'S PROBLEM	E-S-N01-C-009
10056317		02/24/2016	BACK UP IN STATIONARY TUB-23 HENRIETTA	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-010
10056353		02/24/2016	SEWER BACKUP-29 HENRIETTA	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-010
10055557	4051846	02/11/2016	BACKUP-89 LEXINGTON GREEN	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-010-SL
10055564	4051886	02/12/2016	BACK UP-89 LEXINGTON GREEN	FLUSHED LINE/NO BLOCKAGE	E-S-N01-C-010-SL

DISTRICT 4

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10055694		02/19/2016	SEWER BACKUP - 375 STONY RD	HOMEOWNER'S PROBLEM	E-S-N04-C-002
10056314		02/24/2016	SINK HOLE-16 GREEN MEADOW	HOMEOWNER'S PROBLEM	E-S-N04-C-003
10055668		02/19/2016	BACKUP - 26 TAFT	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10056316		02/24/2016	BACK UP IN BASEMENT-5 BISCAYNE	MAIN SURCHARGED DUE TO WEATHER	E-S-N04-C-005
10056354		02/24/2016	SEWER BACKUP-317 BROEZEL	MAIN SURCHARGED DUE TO WEATHER	E-S-N04-C-005
10056315		02/24/2016	BACK UP IN BASEMENT 339 BROEZEL	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10056326	4052885	02/20/2016	SEWER BACKUP-38 BOTIMER ST	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-005-SL
10056357		02/24/2016	SEWER BACKUP-3725 WALDEN	REFERRED TO OTHERS	E-S-N04-C-008
10055645		02/14/2016	BLDG TEMP LOW ALARM-BOWMANSVILLE PS	TELEMETRY/PUMPING STATIONS	E-S-N04-F-BWM
10055512		02/08/2016	CHANNEL MONSTER ALARM @ ECCF	FOLLOW-UP REQUIRED	E-S-N04-F-ECP-WETWL
10055642		02/14/2016	POWER FAIL/GEN RUN-FORESTREAM PS	TELEMETRY/PUMPING STATIONS	E-S-N04-F-FTM

DISTRICT 5

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10056304		02/22/2016	SEWER BACKUP - 8116 CLARHERST DR	HOMEOWNER'S PROBLEM	E-S-N05-C-001
10055695	4051982	02/19/2016	SEWER BACKUP - 6415 WOODBERRY CT	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N05-C-003-SL
10055486		02/07/2016	HIGH EQ TANK LEVEL-CLARENCE RESEARCH PAR	TELEMETRY/PUMPING STATIONS	E-S-N05-F-CRP

NR MECHANICAL ROOT CUTTING - FEBRUARY 2016

DISTRICT 1

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text	Quant.factor
4051845	02/25/2016	TELEWISE/ROOTCUT - JEFFREY DR. PDF*	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB868	104
4051798	02/18/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB866	253
4051861	02/23/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB863	277
4051879	02/20/2016	TELEWISE/ROOTCUT - JOEL DR. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB853	045
4051866	02/23/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB85E	266
4051865	02/23/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB85F	262
4051864	02/19/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB860	056
4051863	02/19/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB861	235
4051799	02/18/2016	TELEWISE/ROOTCUT - GREGORY CT. *PDF	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB867	248
4052691	02/24/2016	TELEWISE/ROOTCUT-JEFFREY DR. PDF*	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB86A	276
4051842	02/25/2016	TELEWISE/ROOTCUT - JEFFREY DR.	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB873	305
4051844	02/25/2016	TELEWISE LINE SEGMENT - JEFFREY DRIVE	MECHANICAL ROOT CUT	E-S-N01-C-004-SL	BB874	109

NR I& I SUMMARY - FEBRUARY 2016

DISTRICT 1

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text
4051515	02/02/2016	REPLACE F & C - CORNER TRANSIT @ MADEIRA	REPLACED FRAME AND COVER(5)	E-S-N01-C-004-MH	BA63E

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
MARCH 2016 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	173	275	120
Stakeouts	78	109	54
TOTAL STAKEOUTS	241		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	7,922	321	0	8,243

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	9,421	1,511	0	10,932
By District				0

	D1	D4	D5	TOTALS
House Inspections		6		6
Reinspections		14		14
Violations		4		4
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	3	0	0	3

Root Treatment (ft)	D1	D4	D5	TOTAL
Vapor Rooting				0
Cutting w/ Flusher	2,295	1,214	0	3,509
Mechanical Cleaning				0

Sewerline Repairs	
SSO's	District #4 172 Seneca Place, Lancaster

CONSTRUCTION		
Mainline	Subdivisions	Commercial
FAIRWAYS @ LANCASTER	SPAULDING GREEN PHASE 3	CIMATO FAMILY BUSINESS PK.
THE BELVEDERE		UPSTATE REBAR-PUNCHLIST

Plans Reviewed:	
	5445 TRANSIT RD. ALTERATIONS
	SIEBERT RD. EXT. PHASE 2

March 2016 Maintenance

District 1

Cayuga

The ORF basins were cleaned after each use.

Began re-programming of the PLC to allow remote operation.

Began replacing wash tank level floats with an ultrasonic level system to eliminate float damage due to ice on the surface of the wash water.

Repaired AVR valve.

Cleaned, scraped, primed and painted all pumps.

Tightened packing gland on ORF flow direction valve to stop small leak.

Cleaned debris from one of the drywell sump pumps. The other pump had a broken shaft and was removed and sent for repair.

District 4

Aurora North

Removed rotating assembly and cleaned blockage from pump casing.

Depew

Began rebuild of spare sewage pump rotating assembly.

Began replacement of hypo feed pump #2 VFD.

Freed frozen generator room ceiling air louvers.

Depew ORF

The ORF basins were cleaned after each use.

Repaired (2) lighting fixtures.

Freed frozen basin return valve.

E.C. Prison Comminutor

Reset Comminutor and checked operation

Forestream

Determined cause of generator overheating to be stuck air intake louvers. Freed and lubricated louver bushings and tested generator after repairs.

Hall

Repaired pump 1 hold-down assembly.

Haskell

Modified motor fan shrouds to allow easier greasing of top bearings.

Iroquois

Reset and checked VFD after power outage.

Warner

Replaced split generator engine coolant hose.

District 4 Offices/Garages

Rebuilt domestic hot water circulating pump.

Repaired unit heater in south garage.

Replaced water cooler filter and adjusted flow rate.

Lubricated booster pumps, glycol circulating pumps, and hot water circulating pumps.

Repaired north garage building heater.

Residential Grinders

414 Harris Hill – Replaced defective grinder pump.

District 5**Bryant**

Tested station bypass pumping system.

Clarence Research

New power transfer switch was successfully tested.

Forestview

Tested station bypass pumping system.

General Maintenance

Existing vehicle AVLs were removed and new units installed.

Rebuilt (3) E-One grinder pumps.

Hydraulic oil samples were taken from all comminutors and the Depew rotary check valve system and sent for analysis.

All facilities were prepared for a DEC/EPA inspection.

All stations were inspected weekly.

Snow removal was performed at all facilities as needed.

Annual preventive maintenance of all portable and stationary generators was completed.

ERIE COUNTY - SEWER DISTRICTS 1,4,5
3/1/2016 TO 4/1/2016
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	4	18	0	22
Taps	0	1	3	4
Disconnect	0	0	0	0
Repair	6	9	0	15
TOTAL	10	28	3	41

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	1	0	1	2
Exist Commercial (EC)	0	0	1	1
New Residential (NR)	5	19	2	26
Exist Residential (ER)	0	0	0	0
TOTAL	6	19	4	29

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	1	2	3
Exist Commercial Issued (EC)	0	0	1	1
New Residential Issued (NR)	4	36	3	43
Exist Residential Issued (ER)	5	9	0	14
TOTAL	9	46	6	61

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 477	\$ 504	\$ 981
Exist Commercial Fees (EC)	\$ 0	\$ 0	\$ 502	\$ 502
New Residential Fees (NR)	\$ 3733	\$ 14197	\$ 2506	\$ 20436
Exist Resident Fees (ER)	\$ 10	\$ 18	\$ 0	\$ 28
TOTAL	\$ 3743	\$ 14692	\$ 3512	\$ 21947

2016 March UFPO Numbers

(By District/Region)

Total UFPO Tickets:	1342
Tickets Outside ECSD Boundary	157

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	173	95	78	13%	16%
District 4	275	161	109	20%	23%
District 5	120	63	54	9%	11%
Total NR	568	319	241	42%	51%

District 3	375	262	113	28%	24%
District 6	45	27	18	3%	4%
District 8	28	20	8	2%	2%
Total CR	448	309	139	33%	29%

District 2	169	74	93	13%	20%
Total SR	169	74	93	13%	20%

Totals:	1185	702	473
----------------	------	-----	-----

Late Tickets

NR	CR	SR
2	3	1

Town of Clarence

2016

District #	Street Address	Date	SBL#	Type	Permit Issued By:
6	5870 Kilkenny Manor	3/1/2016	58.05-5-18	TAP	Clarence
6	6039 Wexford Manor	3/1/2016	44.17-5-14	TAP	Clarence
4	5370 Glenview Dr	3/16/2016	not provided	WYE	Clarence
4	5377 Glenview Dr	3/30/2016	58.16-1-2	WYE	Clarence

NR COMPLAINT SUMMARY - MARCH 2016

DISTRICT 1

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10056831		03/21/2016	CURB & STREET MESS @ 83 OLD STONE RD	REFERRED TO OTHERS	E-S-N01-C-001
10057487	4053667	03/28/2016	SEWER BACKUP 107 JANE DR	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-001-SL
10057499		03/29/2016	SEWAGE OUT OF VENT PIPE-5170 TRANSIT	HOMEOWNER'S PROBLEM	E-S-N01-C-004
10057502		03/25/2016	SEWER BACKUP-26 STRASMER RD	HOMEOWNER'S PROBLEM	E-S-N01-C-004
10056560		03/03/2016	BACKUP-4 DEL	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10056590		03/04/2016	SINK HOLE IN DRIVEWAY-45 PHEASANT LANE	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10057500	4053658	03/24/2016	SEWER BACKUP-760 BORDEN RD	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-007-SL
10056624	4052769	03/07/2016	SINK HOLE 1156 MINERAL SPRINGS	HOMEOWNER'S PROBLEM	E-S-N01-C-010-SL
10057488		03/28/2016	SEWER BACKUP-53 FAIRELM	HOMEOWNER'S PROBLEM	E-S-N01-C-019

DISTRICT 4

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10057530		03/29/2016	SEWAGE OUT OF VENT PIPE-4 BRADLEY	HOMEOWNER'S PROBLEM	E-S-N04-C-003
10056735		03/16/2016	SEWER MAIN HIT BY CONTRACTOR-172 SENECA	FORCEMAIN REPAIRED	E-S-N04-C-005-FM

DISTRICT 5

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10056755		03/14/2016	BACKUP-6460 DEERVIEW CT	HOMEOWNER'S PROBLEM	E-S-N05-C-013

NR I & I SUMMARY - MARCH 2016

I & I REMOVAL

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text
4051978	03/22/2016	INSTALL INFLOW PROTECTOR-50 JOEL DR.	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-004-MH	BA5B5
4052583	03/22/2016	INSTALL IP- 3270 CLINTON BACKLOT	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-009-MH	BB135
4052582	03/22/2016	INSTALL IP- 3270 CLINTON GREGOIRE'S GROV	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-009-MH	BB134

MECHANICAL ROOT CUTTING

DISTRICT 1

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text	Quant.factor
4052796	03/14/2016	ROOTCUT/TELEWISE N. SEINE	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBD46	351
4052845	03/22/2016	ROOTCUT/TELEWISE AUDET	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBDE8	333
4052841	03/24/2016	ROOTCUT/TELEWISE AUDET	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBDEE	346
4052844	03/21/2016	ROOTCUT/TELEWISE AUDET	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBDE6	050
4052843	03/22/2016	ROOTCUT/TELEWISE AUDET	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBDE5	230
4052797	03/14/2016	ROOTCUT/TELEWISE CANNAS CT	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBE23	316
4052846	03/24/2016	ROOTCUT/TELEWISE DANIELLE *PDF*	MECHANICAL ROOT CUT	E-S-N01-C-006-SL	BBC53	400
4052711	03/04/2016	ROOTCUT/TELEWISE PARWOOD	MECHANICAL ROOT CUT	E-S-N01-C-007-SL	BBB10	269

DISTRICT 4

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text	Quant.factor
4052755	03/12/2016	ROOTCUT/TELEWISE IMPALA	MECHANICAL ROOT CUT	E-S-N04-C-005-SL	F29EC	398
4052756	03/12/2016	ROOTCUT/TELEWISE IMPALA	MECHANICAL ROOT CUT	E-S-N04-C-005-SL	F29EA	098
4052754	03/12/2016	ROOTCUT/TELEWISE IMPALA	MECHANICAL ROOT CUT	E-S-N04-C-005-SL	F29EE	376

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
APRIL 2016 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	232	340	213
Stakeouts	98	121	70
TOTAL STAKEOUTS	289		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	1,459	591	727	2,777

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	5,366	591	713	6,670
By District				0

	D1	D4	D5	TOTALS
House Inspections	2	10		12
Reinspections		2		2
Violations	2	8		10
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	0	0	3	3

Root Treatment (ft)	D1	D4	D5	TOTAL
Vapor Rooting				0
Cutting w/ Flusher	4,997	0	0	4,997
Mechanical Cleaning				0

Sewerline Repairs	EMERGENCY SEWER REPAIR @ SENECA CREEK & RANSIER BC29A 10" PIPE
SSO	

CONSTRUCTION		
Mainline	Subdivisions	Commercial
FIRESIDE APTS.	SPAULDING GREEN-PHASE 3	CIMATO FAMILY BUS. PARK
WALDEN PATIOS	CROSS CREEK-PHASE 7	UPSTATE REBAR-PUNCHLIST
THE BELVEDERE		

Plans Reviewed:	JAGG ELECTRIC - D4
	ZOE'S RESTAURANT - D5

April 2016 Maintenance

District 1

Cayuga

The ORF basins were drained and cleaned after each use.
Began repair/replacement of light fixtures in building and wet well.
Performed scheduled maintenance on pump check valves.
Upgrading ORF influent valve for remote operation and improved performance.
Repaired (1) drywell sump pump, removed other pump for rebuild.
Removed #2 washdown pump soft starter for repair.
Inspected rooftop ventilators, cleaned filters as needed.

Industrial Park

Repaired lighting fixtures, purchased LED fixtures to replace un-repairable wet well lighting.
Performed scheduled maintenance on pump check valves.
Inspected rooftop ventilators, cleaned filters as needed.

Mineral Springs

Repaired valve chamber sump pump.

District 4

Bowmansville

Cleared blockage from pump 2.

Depew

Repaired leaks in roof.
Performed scheduled maintenance on pump check valves.
Inspected rooftop ventilators, cleaned filters as needed.

Depew ORF

The ORF basins were drained and cleaned after each use.
Repaired (2) washdown water cannons.

County Prison Comminutor

Cleaned bar screens.

Hall

Removed blockage from pump 2.

Haskell

Repaired roof leak.

Iroquois

Cleaned bar screens.

Pleasantview

Replaced pump seal water filters.

Warner

Cleaned bar screens.

Zoeller

Cleaned bar screens.

District 4 Offices/Garages

Replaced hot water recirculation pump.

Repaired and adjusted office entrance ADA doors.

Repaired west vehicle gate.

All HVAC filters were inspected and replaced as needed.

Replaced defective ballasts on exterior light fixtures.

Replaced faucet in lunch room sink.

All lawn equipment was prepared for use.

District 5

Eastern Hills

Pumped out water meter pit.

Loch Lea

Removed debris from pump 1.

General Maintenance

All stations were inspected weekly.

All emergency standby generators were tested.

Scheduled maintenance was completed on all pump station comminutors.

All pump bypass systems were tested for proper operation.

All facilities were prepared for DEC/EPA inspections.

Lawn and landscape maintenance was performed at all facilities as needed.

ERIE COUNTY - SEWER DISTRICTS 1,4,5
4/1/2016 TO 4/30/2016
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	4	9	1	14
Taps	0	2	0	2
Disconnect	0	1	0	1
Repair	5	12	0	17
TOTAL	9	24	1	34

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	1	1
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	4	11	1	16
Exist Residential (ER)	0	1	0	1
TOTAL	4	12	2	18

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	8	18	2	28
Exist Residential Issued (ER)	4	6	0	10
TOTAL	12	24	2	38

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 0	\$ 0	\$ 0
Exist Commercial Fees (EC)	\$ 0	\$ 0	\$ 0	\$ 0
New Residential Fees (NR)	\$ 6141	\$ 7763	\$ 1004	\$ 14908
Exist Resident Fees (ER)	\$ 8	\$ 12	\$ 0	\$ 20
TOTAL	\$ 6149	\$ 7775	\$ 1004	\$ 14928

DISTRICT #1 CONNECTIONS/ REPAIRS

Date Connected	Permit Number	Address	Town	Code	Type	Owner	Type of Connection
				N or E	S, C, M, or T		
4/4/2016	CP0111670	5060 Transit (Bldg 4)	Cheektowaga	N	M	Pearl's Place	Wye
4/4/2016	CP0111670	5060 Transit (Bldg 5)	Cheektowaga	N	M	Pearl's Place	Wye
4/12/2016	CP0110188	55 South Seine	Cheektowaga	E	S	Charles Cahoon	Repair
4/14/2016	CP0111660	140 Blossomwood	Cheektowaga	N	S	Marrano/Marc Equity	Wye
4/15/2016	CP0109108	210 Sharon Dr	West Seneca	E	S	Mark JHillery	Repair
4/22/2016	CP0111663	100 Blossom Wood	Cheektowaga	N	S	Marrano/Marc Equity	Wye
4/26/2016	CP0100764	108 Autumnwood	Cheektowaga	E	S	Mark Culley	Repair
4/28/2016	CP0101550	296 Barbados	Cheektowaga	E	S	Ken Benware	Repair
4/29/2016	CP0111674	12 Brookfield	Cheektowaga	E	S	Brookfield Condo Assocs /	Repair

DISTRICT #4 CONNECTIONS/REPAIRS

Date Connected	Permit Number	Address	Town	Code	Owner	Type of Connection
				N or E		
4/1/2016	CP0408396	8 Bennington	Lancaster (T)	N	Ryan Homes	Wye
4/5/2016	CP0405156	33 Lake Forest	Lancaster (T)	E	Mike Morreale	Repair
4/5/2016	CP0408439	65,67,69,71 Arborwood (Bldg 24)	Lancaster (T)	N	Juniper Boulevard, LLC	Wye
4/7/2016	CP0408433	337 Pleasant View	Lancaster (T)	N	Marrano/Marc Equity	Wye
4/8/2016	CP0408495	2 Blackstone Ct	Lancaster (T)	N	Robert Briceland	Wye
4/11/2016	CP0408482	364 Aurora	Lancaster (V)	E	Casimer Bukowski	Repair
4/12/2016	CP0408484	19 Albert Ct	Lancaster (V)	E	Steve Hofman	Repair
4/12/2016	CP0408497	5116 Broadway	Depew/Lanc (V)	E	Nicholas Capozzi	Disconnect
4/13/2016	CP0408485	154 Arlington	Depew/Lanc (V)	E	Christine Barth	Repair
4/14/2016	CP0408483	318 Aurora	Lancaster (V)	E	Mary Warner	Repair
4/15/2016	CP0408474	219 Siebert	Lancaster (T)	N	CMK Builders	Tap
4/15/2106	CP0408481	360 Aurora St	Lancaster (V)	E	Gary Knapp	Repair
4/18/2016	CP0408478	200 Seneca Pl	Lancaster (T)	E	Lisa Stanek	Repair
4/18/2016	CP0408505	49 Brady	Lancaster (V)	E	Paul Riter	Repair
4/18/2016	CP0408499	11 Pershing	Lancaster (V)	E	Chris Long / Elite Property Services of WNY	Repair
4/19/2016	CP0408449	3 Magrum	Lancaster (T)	N	Marrano/Marc Equity	Tap
4/19/2016	CP0408443	20 Magrum	Lancaster (T)	N	Marrano/Marc Equity	Wye

4/19/2016	CP0408429	32 Magrum	Lancaster (T)	N	Marrano/Marc Equity	Wye
4/19/2016	CP0408477	284 Seneca Pl	Lancaster (T)	E	Steve McPherson	Repair
4/20/2016	CP0408476	352 Seneca Pl	Lancaster (T)	E	Camille Kaniecki	Repair
4/21/2016	CP0408507	48 Lee St	Depew/Chktg (V)	E	William Petz	Repair
4/22/2015	CP0408450	2 Weathersfield	Lancaster (T)	N	Ryan Homes	Wye
4/22/2016	CP0408444	19 Crabapple	Lancaster (T)	N	Ryan Homes	Wye
4/28/2016	CP0408464	5354-5360 Genesee (Bldg 13)	Lancaster (T)	N	Fairways @ Lancaster, LLC	Wye
4/29/2016	CP0405569	5 Huntington	Lancaster (T)	E	Bill Burker	Repair

DISTRICT #5 CONNECTIONS/REPAIRS

Date Connected	Permit Number	Address	Town	Code	Type	Owner	Type of Connection
				N or E	S, C, M or T		
4/13/2016	CP0503346	4571 Gentwood	Clarence	N	S	Regency Builders	Wye
4/19/2016	CP0503348	10641 Main	Clarence	E	C	Yan Kit Yu / Hollow Bistro Restaurant	Repair

CLARENCE TOWN DISTRICTS

District #	Street Address	Date	Type	Permit Issued By:
4	9739 Silver Birch	4/5/2016	WYE	Clarence
6	6425 Heise Rd	4/7/2016	TAP	Clarence
6	5650 Chatham	4/8/2016	WYE	Clarence
6	5699 Chaham	4/8/2016	WYE	Clarence
6	5876 Kilkenney	4/12/2016	TAP	Clarence
6	5889 Kilkenney	4/12/2016	WYE	Clarence
4	5373 Glenview	4/21/2016	WYE	Clarence
4	5424 Alderbrook	4/21/2016	WYE	Clarence
4	5422 Alberbrook	4/22/2016	WYE	Clarence
2	9284 Kristina	4/26/2016	WYE	Clarence
6	5638 Chatham	4/26/2016	WYE	Clarence
2	9345 Kristina Circle	4/27/2016	TAP	Clarence

NR COMPLAINT SUMMARY - APRIL 2016

DISTRICT 1

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10057600		04/04/2016	BACKUP - 171 VERN LN.	HOMEOWNER'S PROBLEM	E-S-N01-C-001
10058665	4054813	04/25/2016	BACKUP - 15 SOUTH SEINE	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-005-SL
10058719	4053745	04/27/2016	BACKUP - 257 N. SEINE DR.	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-005-SL
10057622		04/18/2016	BACKUP - 75 E. CAVALIER	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10057723		04/11/2016	BACKUP - 55 BRENTWOOD	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10058652		04/23/2016	BACKUP - 14 BRENTWOOD DR	HOMEOWNER'S PROBLEM	E-S-N01-C-007
10056818		04/08/2016	SEWAGE OUT OF VENT PIPE - 91 NORTHWOOD	HOMEOWNER'S PROBLEM	E-S-N01-C-009
10057971	4053744	04/25/2016	BACKUP - 57 ORCHARD PL.	FLUSHED LINE/NO BLOCKAGE	E-S-N01-C-009-SL
10057805		04/13/2016	SINKHOLE - 1205 MINERAL SPRINGS	REFERRED TO OTHERS	E-S-N01-C-010
10057705	4053859	04/08/2016	SINKHOLE - 185 SENECA CREEK RD	REFERRED TO OTHERS	E-S-N01-C-010

DISTRICT 4

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10056666		04/01/2016	BACKUP - 295 IROQUOIS	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10057576		04/01/2016	BACKUP - 6 CHARLTON	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10057621		04/18/2016	SEWAGE OUT OF VENT PIPE-39 QUAIL RUN	HOMEOWNER'S PROBLEM	E-S-N04-C-007

DISTRICT 5

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10058679		04/26/2016	BACKUP - 9099 VIA CIMATO DR	HOMEOWNER'S PROBLEM	E-S-N05-C-004
10057656		04/06/2016	BACKUP - 8960 CANDLEWOOD LN.	HOMEOWNER'S PROBLEM	E-S-N05-C-005
10058009		04/21/2016	SINKHOLE-9368 JUNIPER PL.	REFERRED TO OTHERS	E-S-N05-C-006
10057603		04/04/2016	BACKUP - 5131 BROOKHAVEN	SEE W/O FOR 5201 BROOKHAVEN	E-S-N05-C-009
10057601	4053736	04/04/2016	BACKUP - 5201 BROOKHAVEN	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N05-C-009-SL

NR I & I SUMMARY - APRIL 2016

MH REPAIRS

Order	Malfunct.end	Description	Act. code text	Functional Loc.	Activity text	Quant.factor
4053671	04/01/2016	REPLACE F & C - 6695 TRANSIT RD.	REPLACED FRAME AND COVER(5)	E-S-N05-C-001-MH	C0732	005
4054033	04/14/2016	RAISE MANHOLE TO GRADE-9010 WICKLOW	RAISED MANHOLE(4)	E-S-N05-C-006-MH	1906	000
4054034	04/18/2016	RAISE MANHOLE TO GRADE-8967 WICKLOW	RAISED MANHOLE(4)	E-S-N05-C-006-MH	1914	000

2016 April UFPO Numbers

(By District/Region)

Total UFPO Tickets:	1838
Tickets Outside ECSD Boundary	222

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	232	130	98	13%	18%
District 4	340	216	121	18%	22%
District 5	213	144	70	12%	13%
Total NR	785	490	289	43%	53%

District 3	520	372	140	28%	26%
District 6	53	35	17	3%	3%
District 8	62	59	3	3%	1%
Total CR	635	466	160	35%	29%

District 2	196	95	97	11%	18%
Total SR	196	95	97	11%	18%

Totals:	1616	1051	546		
----------------	------	------	-----	--	--

Late Tickets

NR	CR	SR
2	3	0