

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
JANUARY 2015 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	91	130	67
Stakeouts	37	66	21
TOTAL STAKEOUTS	124		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	1,561	1,677	0	3,238

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District				0

	D1	D4	D5	TOTALS
House Inspections	5	1		6
Reinspections	1	2		3
Violations	2	1		3
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	4	0	0	4

Root Treatment (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut				0
Mechanically Cleaned				0

Sewerline Repairs	SEE ATTACHED REPORT

CONSTRUCTION		
Mainline	Subdivisions	Commercial
VERONICA ESTATES	CROSS CREEK - PHASE 6	UPSTATE REBAR-PUNCHLIST
EDGEWATER APTS.	WINDSOR RIDGE SOUTH PH. 1A	GABE'S COLLISION
	SPAULDING GREEN PH. 6A	

Plans Reviewed:

NR I & I SUMMARY - JANUARY 2015

MANHOLE REPAIRS

Order	Malfunction	Description	Act. code text	Functional Loc.	Activity text	Quant. factor
4037774	01/08/2015	CLEAN OFF MH COVER @ 32 FELBER	REPAIRED MANHOLE - NOT I & I RELATED	E-S-N01-C-001-MH	BA4AD	0
4037069	01/05/2015	MANHOLE REPAIR-17 BELLEVUE & PARK	REPAIRED FRAME/CONE JOINT LEAKS, MOD(4)	E-S-N01-C-001-MH	BA402	4
4037786	01/06/2015	MANHOLE REPAIR-BENNETT AND HOMEWOOD	REPLACED COVER	E-S-N01-C-001-MH	BA3D4	0
4036867	01/05/2015	MANHOLE REPAIR-34 SENECA CREEK	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-010-MH	BB0C7	3

SEWERLINE REPAIRS

Order	Malfunction	Description	Act. code text	Functional Loc.	Activity text	Quant. factor
4037626	1/16/2015	SEWER LINE REPAIR (DF4D5) 156 WENDELL ST	PIPE REPLACED - 8"	E-S-N04-C-008-SL	DF4D5	4
4037685	1/29/2015	F. M. REPAIR @ BOATHOUSE P. S.	REPAIRED	E-S-N01-F-BTH	141	0

NR COMPLAINT SUMMARY - JANUARY 2015

DISTRICT 1

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10040060		01/07/2015	SEWER BACKUP-2223 UNION ST	HOMEOWNER'S PROBLEM	E-S-N01-C
10040580		01/14/2015	SEWER BACKUP-175 FRENCH LEA	HOMEOWNER'S PROBLEM	E-S-N01-C
10040752		01/31/2015	SEWER BACKUP-128 STRASMER	HOMEOWNER'S PROBLEM	E-S-N01-C
10040674	4037716	01/18/2015	SEWER BACKUP-27 ARMOND LANE	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-004-SL
10040050	4036879	01/07/2015	ROOTS IN MAIN LINE-46 MAPLEWOOD AVE	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-009-SL
10039802	4036807	01/04/2015	WATER HIGH IN MANHOLE-34 SENECA CREEK	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-010-SL

DISTRICT 4

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10039803	4036808	01/04/2015	SEWER BACKUP-38 PARKDALE DR	HOMEOWNER'S PROBLEM	E-S-N04-C
10039997		01/13/2015	MANHOLE COVER MISSING-415 AURORA ST	REFERRED TO OTHERS	E-S-N04-C
10040058	4036878	01/09/2015	MANHOLE HIT BY PLOW-TRANSIT RD@ WILLIAM	PUT ON LIST TO REPAIR	E-S-N04-C
10040711		01/21/2015	SEWER BACKUP-729 PLEASANTVIEW	HOMEOWNER'S PROBLEM	E-S-N04-C
10040742		01/26/2015	SEWER BACKUP-24 HERITAGE DR	HOMEOWNER'S PROBLEM	E-S-N04-C
10040753		01/31/2015	SEWER BACKUP-25 COUNTRY PLACE	HOMEOWNER'S PROBLEM	E-S-N04-C
10040710	4037712	01/20/2015	SEWER ODOR-2781 TOWN LINE	ODOR-FLUSHED LINE/NO BLOCKAGE	E-S-N04-C-007-SL
10040582	4037718	01/15/2015	SEWER BACKUP-156 WENDEL	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-008-SL
10040714	4037711	01/22/2015	SEWER BACKUP-156 WENDEL	FLUSHED LINE/NO BLOCKAGE	E-S-N04-C-008-SL

DISTRICT 5

Notification	Order	Notif.date	Description	Prob. code text	Functional Loc.
10040712		01/21/2015	SEWER BACKUP-4880 WEST AVE	HOMEOWNER'S PROBLEM	E-S-N05-C

January 2015 Maintenance

District 1

Borden

Replaced pump 1 rotating assembly with spare.
Began rebuild of pump 1 rotating assembly for use as spare.

Cayuga

Repaired leak in ORF redirection valve.
Rebuilt and installed ORF basin return gate actuator.
Removed boiler circulating pump for rebuild.

Frank Lloyd Wright Boathouse

Repaired broken force main.
Replaced pump 1.

District 4

Bowmansville

Removed debris from Comminutor.
Removed debris from pump 2.

Broadway East

Reset VFD after power outage.

Depew

Repaired (3) light fixtures.
Freed stuck rotary check valves 1 and 2.

Iroquois

Completed replacement of drywell pump-level lighting.

Pleasantview

Completed pump rebuild and installed rebuilt pump.

Warner

Reset pump 1.
Replaced bubbler system with submersible pressure transducer level sensor.

District 4 Offices/Garages

Repaired office water fountain.

Filled glycol feed system.

Cleaned heat pump sediment screens.

General Maintenance

All stations were inspected.

Snow/Ice removal was performed at all facilities as needed.

Scheduled maintenance was performed on all comminutors.

Scheduled maintenance was performed on all standby generators.

ERIE COUNTY - SEWER DISTRICTS 4
1/1/2015 TO 1/31/2015
OPERATION REPORT

INSPECTIONS	D4	TOTAL
Wyes	6	6
Taps	2	2
Disconnect	0	0
Repair	4	4
TOTAL	12	12

CONNECTIONS	D4	TOTAL
New Commercial (NC)	0	0
Exist Commercial (EC)	0	0
New Residential (NR)	8	8
Exist Residential (ER)	8	8
TOTAL	8	8

PERMITS	D4	TOTAL
New Commercial Issued (NC)	1	1
Exist Commercial Issued (EC)	0	0
New Residential Issued (NR)	21	21
Exist Residential Issued (ER)	12	12
TOTAL	34	34

PERMIT FEES	D4	TOTAL
New Commercial Fees (NC)	\$ 502	\$ 502
Exist Commercial Fees (EC)	\$ 0	\$ 0
New Residential Fees (NR)	\$ 14067	\$ 14067
Exist Resident Fees (ER)	\$ 24	\$ 24
TOTAL	\$ 14593	\$ 14593

ERIE COUNTY - SEWER DISTRICTS 1
1/1/2015 TO 1/31/2015
OPERATION REPORT

INSPECTIONS	D1	TOTAL
Wyes	0	0
Taps	0	0
Disconnect	0	0
Repair	4	4
TOTAL	4	4

CONNECTIONS	D1	TOTAL
New Commercial (NC)	0	0
Exist Commercial (EC)	0	0
New Residential (NR)	0	0
Exist Residential (ER)	0	0
TOTAL	0	0

PERMITS	D1	TOTAL
New Commercial Issued (NC)	0	0
Exist Commercial Issued (EC)	0	0
New Residential Issued (NR)	4	4
Exist Residential Issued (ER)	3	3
TOTAL	7	7

PERMIT FEES	D1	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 0
Exist Commercial Fees (EC)	\$ 0	\$ 0
New Residential Fees (NR)	\$ 1508	\$ 1508
Exist Resident Fees (ER)	\$ 6	\$ 6
TOTAL	\$ 1514	\$ 1514

ERIE COUNTY - SEWER DISTRICTS 5
1/1/2015 TO 1/31/2015
OPERATION REPORT

INSPECTIONS	D5	TOTAL
Wyes	0	0
Taps	0	0
Disconnect	0	0
Repair	1	1
TOTAL	1	1

CONNECTIONS	D5	TOTAL
New Commercial (NC)	0	0
Exist Commercial (EC)	0	0
New Residential (NR)	0	0
Exist Residential (ER)	0	0
TOTAL	0	0

PERMITS	D5	TOTAL
New Commercial Issued (NC)	0	0
Exist Commercial Issued (EC)	0	0
New Residential Issued (NR)	0	0
Exist Residential Issued (ER)	1	1
TOTAL	1	1

PERMIT FEES	D5	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 0
Exist Commercial Fees (EC)	\$ 0	\$ 0
New Residential Fees (NR)	\$ 0	\$ 0
Exist Resident Fees (ER)	\$ 2	\$ 2
TOTAL	\$ 2	\$ 2

DISTRICT 1

Date Connected	Permit Number	Address	Town	Contractor	Inspector	Type of Connection
1/14/2015	CP0106573	48 John Brian Lane	Cheektowaga	Superior Plumbing	T Notaro	Repair
1/21/2015	CP0101615	132 Baywood	Cheektowaga	Roto Rooter	T Notaro	Repair
1/21/2015	CP0102880	580 Como Park Blvd	Cheektowaga	T-Mark Plumbing	T Notaro	Repair
1/29/2015	CP0111635	53 Ashleaf Dr	Cheektowaga	Roto Rooter	T Notaro	Repair

DISTRICT 4

Date Connected	Permit Number	Address	Town	Contractor	Inspector	Type of Connection
1/1/2015	CP0408130	16 Silent Meadow	Lancaster (T)	G & K Sewer	Tony Notaro	Wye
1/5/2015	CP0408177	23 Pear Tree Lane	Lancaster (T)	G & K Sewer	Tony Notaro	Wye
1/6/2015	CP0408159	13 15 Cumberland	Lancaster (T)	G & K Sewer	Tony Notaro	Wye
1/7/2015	CP0408198	493 Lake Ave	Lancaster (T)	Cellino Plumbing	Tony Notaro	Repair
1/12/2015	CP0408149	17 Silent Meadow	Lancaster (T)	G & K Sewer	Tony Notaro	Wye
1/15/2015	CP0408173	29 Middlebury Lane	Lancaster (T)	ECI	Tony Notaro	Wye
1/16/2015	CP0404450	70 Pheasant Run	Lancaster (T)	DGR Plumbing	T Herr	Repair
1/21/2015	CP0408157	153 Wendel	Lancaster (T)	Great Lakes Plumbing	J Bartolotta	Tap
1/21/2015	CP0408156	149 Wendel	Lancaster (T)	Great Lakes Plumbing	J Bartolotta	Tap
1/23/2015	CP0403195	6 Spruceland	Lancaster (T)	Roto Rooter	Tony Notaro	Repair
1/26/2015	CP0408163	13 Branch Way	Lancaster (T)	G & K Sewer	Faragiano	Wye
1/27/2015	CP0408208	157 Kieffer Ave	Depew/Lanc (V)	Roto Rooter	Tony Notaro	Repair
1/28/2015	CP0407373	18 Parkdale	Lancaster (T)	G & k Sewer	Tony Notaro	Repair

DISTRICT 5

Date Connected	Permit Number	Address	Town	Contractor	Inspector	Type of Connection
1/27/2015	CP0503319	9500 Transit Rd	Amherst	Kimil Construction	Tony Notaro	Tap

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
FEBRUARY 2015 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTAL	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	60	72	54
Stakeouts	34	22	29
TOTAL STAKEOUTS	85		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	700	957	220	1,877

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	0	605	0	605
By District	0	0	0	0

	D1	D4	D5	TOTAL
House Inspections	1			1
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	0	0	0	0

Root Treatment (ft)	D1	D4	D5	TOTAL
Vapor Rooting				0
Cutting w/ Flusher				0
Mechanical Cleaning				0

Sewerline Repairs	D1	D4	D5	TOTAL

CONSTRUCTION		
Mainline	Subdivisions	Commercial
VERONICA ESTATES	CROSS CREEK - PHASE 6	UPSTATE REBAR-PUNCHLIST
EDGEWATER APTS.	WINDSOR RIDGE SOUTH PH. 1A	GABE'S COLLISION

Plans Reviewed:	

SSO'S	

ERIE COUNTY - SEWER DISTRICTS 1,4,5
2/1/2015 TO 2/28/2015
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	1	0	1
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	3	1	0	4
TOTAL	3	2	0	5

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	1	0	1
Exist Residential (ER)	0	0	0	0
TOTAL	0	1	0	1

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	1	0	1
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	0	8	0	8
Exist Residential Issued (ER)	3	2	1	6
TOTAL	3	11	1	15

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$ 0	\$ 502	\$ 0	\$ 502
Exist Commercial Fees (EC)	\$ 0	\$ 0	\$ 0	\$ 0
New Residential Fees (NR)	\$ 0	\$ 4016	\$ 0	\$ 4016
Exist Resident Fees (ER)	\$ 6	\$ 4	\$ 2	\$ 12
TOTAL	\$ 6	\$ 4522	\$ 2	\$ 4530

DISTRICT #1

2/6/2015	CP0111636	66 Broadway 12 North	West Seneca	E	A Gareleck & Sons	Gerarld Bommer	Repair
2/16/2015	CP0107400	Rushford	Cheektowaga	E	Roto Rooter	Catherine Davis	Repair
2/24/2015	CP0104948	35 Felber Lane	Cheektowaga	E	Mr Plumber	William Mcinnis	Repair

DISTRICT #4

2/9/2015	CP0408174	22 Middlebury Lane	Lancaster (T)	N	ECI	Ryan Homes	Wye
2/11/2015	CP0402678	190 Stony Rd	Lancaster (T)	E	Superior Plumbing	Craig Alessandra	Repair

DISTRICT #5

NO CONNECTIONS OR REPAIRS FOR THE MONTH OF FEBRUARY

2015 February UFPO Numbers

(By District/Region)

Total UFPO Tickets:	550
Tickets Outside ECSD Boundary	58

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	60	23	34	11%	13%
District 4	72	46	22	13%	9%
District 5	54	25	29	10%	11%
Total NR	186	94	85	34%	33%

District 3	165	85	75	30%	30%
District 6	48	14	34	9%	13%
District 8	21	7	14	4%	6%
Total CR	234	106	123	43%	48%

District 2	72	25	46	13%	18%
Total SR	72	25	46	13%	18%

Totals:	492	225	254		
----------------	-----	-----	-----	--	--

Late Tickets

NR	CR	SR
0	0	0

NR COMPLAINT SUMMARY - FEBRUARY 2015

DISTRICT 1

Notification	Order	Notif. date	Description	Prob. code text	Functional Loc.
10041798		02/23/2015	SEWER ISSUE-35 FELBER LANE	REFERRED TO OTHERS	E-S-N01-C-001
10041799		02/24/2015	SEWER BACKUP-73 DEER CHASE RD	HOMEOWNER'S PROBLEM	E-S-N01-C-001
10040989	4038761	02/12/2015	SEWER BACKUP-27 SHERRY DR	FLUSHED LINE/NO BLOCKAGE	E-S-N01-C-004-SL
10041791	4038803	02/20/2015	SEWER BACKUP-103 SEBRING	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-004-SL
10041005	4038059	02/08/2015	SEWER BACKUP-1040 MINERAL SPRINGS RD	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-010-SL
10040958		02/04/2015	SEWER BACKUP-114 FAIRELM	HOMEOWNER'S PROBLEM	E-S-N01-C-019

DISTRICT 4

Notification	Order	Notif. date	Description	Prob. code text	Functional Loc.
10041735		02/17/2015	SEWER ODOR-4723 TRANSIT	HOMEOWNER'S PROBLEM	E-S-N04-C
10041800		02/24/2015	SEWER BACKUP-481 HARRIS HILL	HOMEOWNER'S PROBLEM	E-S-N04-C-001
10041734		02/17/2015	SEWER BACKUP-200 SENECA PLACE	HOMEOWNER'S PROBLEM	E-S-N04-C-005
10041822		02/26/2015	SEWER BACKUP-420 AURORA ST	HOMEOWNER'S PROBLEM	E-S-N04-C-008
10041063	4038699	02/16/2015	SEWER BACKUP-156 WENDEL ST	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-008-SL
10041801		02/26/2015	SEWER BACKUP-4852 WILLIAM ST	HOMEOWNER'S PROBLEM	E-S-N04-C-013
10040988		02/11/2015	SEWER BACKUP-7 HEMLOCK LANE	HOMEOWNER'S PROBLEM	E-S-N04-C-016

DISTRICT 5

Notification	Order	Notif. date	Description	Prob. code text	Functional Loc.
10040959	4038760	02/05/2015	SEWER BACKUP-8270 WEHRLE DR	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N05-C-008-SL

January 2015 Maintenance

District 1

Borden

Replaced pump 1 rotating assembly with spare.
Began rebuild of pump 1 rotating assembly for use as spare.

Cayuga

Repaired leak in ORF redirection valve.
Rebuilt and installed ORF basin return gate actuator.
Removed boiler circulating pump for rebuild.

Frank Lloyd Wright Boathouse

Repaired broken force main.
Replaced pump 1.

~~**Mineral Springs**~~

Completed installation or repaired Telog unit.

District 4

Bowmansville

Removed debris from Comminutor.
Removed debris from pump 2.

Broadway East

Reset VFD after power outage.

Depew

Repaired (3) light fixtures.
Freed stuck rotary check valves 1 and 2.

Iroquois

Completed replacement of drywell pump-level lighting.

Pleasantview

Completed pump rebuild and installed rebuilt pump.

Warner

Reset pump 1.
Replaced bubbler system with submersible pressure transducer level sensor.

District 4 Offices/Garages

Repaired office water fountain.
Filled glycol feed system.
Cleaned heat pump sediment screens.

General Maintenance

All stations were inspected.

Snow/Ice removal was performed at all facilities as needed.

Scheduled maintenance was performed on all comminutors.

Scheduled maintenance was performed on all standby generators.