ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
SEPTEMBER 2013 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection		16	5
Grinder			
TOTALS	0	16	5
		21	

UFPO's	D1	D4	D5
Responses	189	240	131
Stakeouts	38	76	49
TOTAL STAKEOUTS	163		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	4,639	30,680	16,521	51,840

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District				0

	D1	D4	D5	TOTALS
House Inspections	1		20	21
Reinspections			6	6
Violations			3	3
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	5	2	1	8

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut				0
Mechanically Cleaned	345	0	0	345

Sewerline Repairs

CONSTRUCTION		
Mainline	Subdivisions	Commercial
ROLL RD. SENIOR HOUSING		UPSTATE REBAR-PUNCHLIST
8880 CLARENCE CENTER RD.		4534 CLINTON-FIELDWALK
SPAULDING GREEN PHASE 2D		
CROSS CREEK PHASE 4		

Plans Reviewed:
CHECKERS RESTAURANT - 2565 UNION RD. CHEEKTOWAGA
HIDDEN PINES SUB. PHASE 2
8321 MAIN ST. CLARENCE - OUT OF DISTRICT, NON-RESIDENTIAL

Item 6a

NR COMPLAINTS - DISTRICT 1

10022647	4021172	09/21/2013 CM	BACKUP-100 FAIR ELM-FLUSHED/RELIEVED	SCMPLT	OBSTARCM	E-S-N01-C
10022768		09/27/2013 CM	BACKUP-110 FAIRELM-H/O PROBLEM	SCMPLT	REHACB	E-S-N01-C
10021794		09/05/2013 CM	BACKUP-115 TOWERS-H/O PROBLEM	SCMPLT	REHACB	E-S-N01-C
10021901		09/17/2013 CM	BACKUP-131 N SEINE-FLUSHED/RELIEVED	SCMPLT	REHACB	E-S-N01-C
10022681		09/21/2013 CM	BACKUP-2378 UNION RD-WEATHER RELATED	SCMPLT	OBSTARCM	E-S-N01-C
10022661		09/21/2013 CM	BACKUP-2559 WILLIAM-REFERRED TO OTHERS	SCMPLT	OBSTARCM	E-S-N01-C
10022688		09/28/2013 CM	BACKUP-39 FAIR ELM-H/O PROBLEM	SCMPLT	WEDZINAF	E-S-N01-C
10022580		09/20/2013 CM	BACKUP-82 HILLWOOD-REFERRED TO OTHERS	SCMPLT	REHACB	E-S-N01-C
10022683		09/26/2013 CM	BACKUP-95 AUTUMNWOOD-H/O PROBLEM	SCMPLT	MURRAYK	E-S-N01-C
10021876		09/15/2013 CM	EMERG UFPO-116 ELECTRIC AVE	SCMPLT	KWIATEKP	E-S-N01-C
10022572		09/21/2013 CM	EMERG UFPO-2959 TRANSIT	SCMPLT	PINGITON	E-S-N01-C
10022682		09/25/2013 CM	MH ROOT ISSUES-83 FRENCH LEA	SCMPLT	MURRAYK	E-S-N01-C
10022769		09/27/2013 CM	ODOR-24 BROOKFIELD-REFERRED TO OTHERS	SCMPLT	REHACB	E-S-N01-C
10022583		09/23/2013 CM	ODOR-4805 TRANSIT-REFERRED TO OTHERS	SCMPLT	MURRAYK	E-S-N01-C
10022665	4021162	09/21/2013 CM	BACKUP-111 AUDET DR-FLUSHED/RELIEVED	SCMPLT	OBSTARCM	E-S-N01-C-005-SL
10021902	4021160	09/17/2013 CM	BACKUP-135 N SEINE-FLUSHED/RELIEVED	SCMPLT	REHACB	E-S-N01-C-005-SL
10022662	4021161	09/21/2013 CM	BACKUP-95 AUDET-FLUSHED/RELIEVED	SCMPLT	PINGITON	E-S-N01-C-005-SL
10021859	4020307	09/19/2013 CM	BACKUP-106 HILLWOOD-FLUSHED/RELIEVED	SCMPLT	HERRT	E-S-N01-C-007-SL
10022767	4021110	09/27/2013 CM	REPLACED F/C, 200 ST. JUDE TER	SCMPLT	REHACB	E-S-N01-C-009-MH
10021844	4020308	09/09/2013 CM	BACKUP-3424 CLINTON-FLUSHED/NO BLOCKAGE	SCMPLT	MURRAYK	E-S-N01-C-009-SL
10021633	4020213	09/03/2013 CM	BACKUP-67 BOSSE LN-FLUSHED/RELIEVED	SCMPLT	REHACB	E-S-N01-C-009-SL

NR COMPLAINTS - DISTRICT 4

10021838		09/12/2013 CM	BACKUP-1181 PENORA-H/O PROBLEM	SCMPLT	SMOOTR	E-S-N04-C
10022581		09/23/2013 CM	BACKUP-147 BELMONT-STORM SEWER ISSUE	SCMPLT	MURRAYK	E-S-N04-C
10022680		09/22/2013 CM	BACKUP-17 TAFT AVE-WEATHER RELATED	SCMPLT	PINGITON	E-S-N04-C
10022668		09/21/2013 CM	BACKUP-18 MEADOW LEA-WEATHER RELATED	SCMPLT	MCDONAJ2	E-S-N04-C
10022648		09/21/2013 CM	BACKUP-18 TAFT-WEATHER RELATED	SCMPLT	OBSTARCM	E-S-N04-C
10022669		09/21/2013 CM	BACKUP-266 IROQUOIS AVE-WEATHER RELATED	SCMPLT	GUADAGNK	E-S-N04-C
10022664		09/21/2013 CM	BACKUP-275 BROEZEL-WEATHER RELATED	SCMPLT	OBSTARCM	E-S-N04-C
10022649		09/21/2013 CM	BACKUP-29 TAFT-WEATHER RELATED	SCMPLT	OBSTARCM	E-S-N04-C
10022663		09/21/2013 CM	BACKUP-49 CHARLTON-WEATHER RELATED	SCMPLT	OBSTARCM	E-S-N04-C
10022646		09/21/2013 CM	BACKUP-617 COLUMBIA-WEATHER RELATED	SCMPLT	OBSTARCM	E-S-N04-C
10022582		09/23/2013 CM	MH IN SIDEWALK RAISED-27 STEINFELDT	SCMPLT	MURRAYK	E-S-N04-C
10022667		09/21/2013 CM	ODOR-259 BROEZEL-WEATHER RELATED	SCMPLT	MCDONAJ2	E-S-N04-C
10021875		09/14/2013 CM	ODOR-41 SUSSEX-STORM SEWER ISSUE	SCMPLT	WEDZINAF	E-S-N04-C
10022770		09/27/2013 CM	SIDEWALKS CRACKED-9 OLD POST	SCMPLT	REHACB	E-S-N04-C
10021900		09/16/2013 CM	VACANT LOT COVER ISSUE-339-353 IROQUOIS	SCMPLT	GANNONT	E-S-N04-C
10021792	4020253	09/04/2013 CM	BACKUP-5002 WILLIAM-FLUSHED/RELIEVED	SCMPLT	MURRAYK	E-S-N04-C-013-SL

NR COMPLAINTS - DISTRICT 5

10022684		09/24/2013 CM	BACKUP-10645 BOYD-H/O PROBLEM	SCMPLT	GANNONT	E-S-N05-C
10021662		09/02/2013 CM	EMERG UFPO-5876 NEW HOUSE RD	SCMPLT	SMOOTR	E-S-N05-C
10021635		09/03/2013 CM	MANHOLE COVER LOOSE-ROLL RD & TRANSIT	SCMPLT	REHACB	E-S-N05-C
10021636		09/03/2013 CM	ODOR COMPLAINT-CORRINNE	SCMPLT	REHACB	E-S-N05-C
10021637		09/04/2013 CM	ODOR-6065 CORRINNE-NOT SANITARY RELATED	SCMPLT	REHACB	E-S-N05-C
10021634		09/03/2013 CM	ODOR-8964 SHANNON-NOT SANITARY RELATED	SCMPLT	REHACB	E-S-N05-C
10021892		09/12/2013 CM	SINKING GROUND AROUND MH-6275 JENNIFER	SCMPLT	REHACB	E-S-N05-C
10021836	4020310	09/11/2013 CM	BACKUP-9450 TRANSIT-FLUSHED/RELIEVED	SCMPLT	REHACB	E-S-N05-C-001-SL
10021793	4020254	09/04/2013 CM	BACKUP-9370 CLAR. CTR.-FLUSHED/RELIEVED	SCMPLT	REHACB	E-S-N05-C-006-SL

NR MECHANICAL CLEANING

4021034	09/11/2013	MECHANICAL CLEANING, AMERICAN PIPE,BC13C	MECHANICALLY CLEANED PIPE	040	E-S-N01-C-010-SL	BC13C
4020251	09/11/2013	MECHANICAL CLEANING,AMERICAN PIPE, BC13B	MECHANICALLY CLEANED PIPE	305	E-S-N01-C-010-SL	BC13B

[redacted]	Malfunct.end	Descripon	Act. code text	Quant.factor	Funconal Loc.	Acvity text
4021087	09/25/2013	CHIMNEY SEAL, S0 MADEIRA DR	REPAIRED BARREL JOINT LEAKS, MOO(4)	004	E-S-N01-C-004-MH	BA64S
4021086	09/25/2013	CHIMNEY SEAL, 51 JOEL DR	REPAIRED CONE/BARREL JOINT LEAKS, SLT(3)	003	E-S-N01-C-004-MH	BA5BA
4021083	09/25/2013	CHIMNEY SEAL, 4 FLORETTE DR	REPAIRED CONE/BARREL JOINT LEAKS, SLT(3)	003	E-S-N01-C-007-MH	BB35D
4021085	09/25/2013	CHIMNEY SEAL, 46 DEE TER	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	004	E-S-N01-C-007-MH	BB2DD
4021084	09/25/2013	CHIMNEY SEAL, 19 DAVIDSON DR	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	004	E-S-N01-C-007-MH	BA672
4020257	09/26/2013	REPLACED F/C, NE WALDEN & BROEZEL	REPLACED FRAME AND COVER(5)	005	E-S-N04-C-005-MH	EAC6F
4020258	09/26/2013	REPLACED F/C, NW WALDEN & BROEZEL	REPLACED FRAME AND COVER(5)	005	E-S-N04-C-005-MH	EAC70
4019959	09/04/2013	REPLACED F/C, 8030 ROLL RD	REPLACED FRAME AND COVER(5)	005	E-S-N05-C-007-MH	C0883

ERIE COUNTY - SEWER DISTRICTS 1,4,5
9/1/2013 TO 9/30/2013
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	10	4	14
Taps	0	6	1	7
Disconnect	0	0	0	0
Repair	1	2	0	3
TOTAL	1	18	5	24

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	17	5	22
Exist Residential (ER)	0	0	0	0
TOTAL	0	17	5	22

PERMITS	DI	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	1	6	5	12
Exist Residential Issued (ER)	2	1	0	3
TOTAL	3	7	5	15

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	$ 0	$ 0	$ 0	$ 0
Exist Commercial Fees (EC)	$ 0	$ 0	$ 0	$ 0
New Residential Fees (NR)	$ 502	$ 1012	$ 1010	$ 2524
Exist Resident Fees (ER)	$ 4	$ 2	$ 0	$ 6
TOTAL	$ 506	$ 1014	$ 1010	$ 2530

September 2013 Maintenance

District 1

Cayuga
Continued upgrade of pump VFD's.
Cleaned and tested pump Air/Vacuum valves.

Frank Lloyd Wright Boathouse
Replaced start/run components for pump 2.

Industrial Park
Continued work on rebuilding spare pumps.
Removed debris from pumps 3 & 4.

Mineral Springs
Pumped ground water from meter pit.

District 4

Bowmansville
Completed programming and installation of upgraded pump control system.
Removed debris from pump 2.

Depew
Changed comminutors' hydraulic oil and filters.

Iroquois
A loose pump inspection plate caused the drywell to flood., submerging all underground equipment. We pumped down the wetwell with a portable bypass pump, flushed all equipment with distilled water and isopropyl alcohol. Both pump motors were sent for repair. The manlift brakemotor was un-repairable and a replacement will be ordered.

Pleasantview
Removed defective dry well ventilation blower for replacement.

Warner
Repaired a generator fuel leak.

Zoeller
A large amount of debris was vacuumed from wet well.

District 4 Offices/Garages
Inspected heat pumps, changed/cleaned filters as needed.
Cleaned cooling tower spray water sump.

District 5

Clarence Research STP
Replaced west media pump control transformer after lightning strike.
Installed new aerators in equalization tank.
Replaced the motor for blower #2.

****MCC PANEL?

Dodge
Completed repairs to equipment damaged by vehicle collision.

Loch Lea
Pulled pump and removed debris from impeller.

General Maintenance

Began replacement of all Camlock fittings with Bauer fittings on pump station bypass systems and portable pumps.

All stations were inspected weekly.

Lawn and landscape maintenance was performed at all facilities as needed.

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
OCTOBER 2013 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection	3	14	3
Grinder			
TOTALS	3	14	3
	20		

UFPO's	D1	D4	D5
Responses	194	152	124
Stakeouts	42	68	51
TOTAL STAKEOUTS	161		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	13,974	52,190	6,970	73,134

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District	2	0	0	2

	D1	D4	D5	TOTALS
House Inspections	106		6	112
Reinspections	29	1	13	43
Violations	57		5	62
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	9	1	0	10

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut				0
Mechanically Cleaned				0

Sewerline Repairs	
Misc. Items	SSO @ 70 Empire Drive, West Seneca October 18, 2013

CONSTRUCTION		
Mainline	Subdivisions	Commercial
CROSS CREEK PHASE 4		UPSTATE REBAR-PUNCHLIST
CREEKSIDE @ PLEASANT MEADOWS		4534 CLINTON-FIELDWALK
ROLL RD. SENIOR HOUSING		

Plans Reviewed:	CAMP BOW WOW - D1 - WEST SENECA

NR MANHOLE REPAIRS - OCTOBER 2013

4021920	10/29/2013	REPLACE F/C, 54 BELLEVUE AVE	REPLACED FRAME AND COVER(5)	005	E-S-N01-C-001-MH	BA3F2
4021861	10/21/2013	REPLACE F/C, 7 JEROME	REPLACED FRAME AND COVER(5)	005	E-S-N01-C-002-MH	BAB41
4021089	10/02/2013	CHIMNEY SEAL, 140 SEBRING DR	REPAIRED CONE/BARREL JOINT LEAKS, SLT(3)	003	E-S-N01-C-004-MH	BA630
4021088	10/02/2013	CHIMNEY SEAL, 54 LEMANS DR	REPAIRED CONE/BARREL JOINT LEAKS, SLT(3)	003	E-S-N01-C-004-MH	BA601
4021864	10/24/2013	MH ROOT ISSUES-83 FRENCH LEA	REPAIRED FRAME, NOT JOINT LEAKS, MOD(4)	004	E-S-N01-C-007-MH	BB21D
4021860	10/21/2013	RESET FRAME, 2442 UNION RD.	REPAIRED FRAME, NOT JOINT LEAKS, MOD(4)	004	E-S-N01-C-008-MH	BA903
4021110	10/01/2013	REPLACED F/C, 200 ST. JUDE TER	REPLACED FRAME AND COVER(5)	005	E-S-N01-C-009-MH	BB246
4021110	10/01/2013	REPLACED F/C, 200 ST. JUDE TER	INSTALLED INFLOW PROTECTOR (4)	000	E-S-N01-C-009-MH	BB246
4021925	10/30/2013	REPLACE F/C, 4831 CLINTON ST	REPLACED FRAME AND COVER(5)	005	E-S-N01-C-009-MH	BA76F
4021924	10/25/2013	REPLACE F/C, 870 MINERAL SPRINGS	REPLACED FRAME AND COVER(5)	005	E-S-N01-C-010-MH	BAFC7
4021919	10/28/2013	RAISED MANHOLE, WILLIAM ST	RAISED MANHOLE(4)	004	E-S-N04-C-011-MH	DEE00

NR COMPLAINTS - DISTRICT 1

10023636		10/30/2013	CM	BACKUP-104 SOUTH SEINE-H/O PROBLEM	1	SCMPLT	D160	SMOOTR	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/08/2013	HERRT
10023536		10/19/2013	CM	BACKUP-73 ORCHARD-H/O PROBLEM	1	SCMPLT	D160	SMOOTR	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/06/2013	HERRT
10023626		10/27/2013	CM	EMERGENCY UFPO-134 NORTH AVE	1	SCMPLT	D160	JAMESI	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/07/2013	ABSOLOMG
10023624		10/26/2013	CM	EMERGENCY UFPO-18 JEFFREY	1	SCMPLT	D190	WEDZINAF	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/07/2013	ABSOLOMG
10023555		10/21/2013	CM	ODOR COMPLAINT-17 GRAND PRIX	1	SCMPLT	D160	GANNONT	Norman H Moorhouse	E-S-N01-C	KASZUBOM		11/06/2013	HERRT
10023551		10/17/2013	CM	SINK HOLE-323 CASIMER-DYE TEST NEGATIVE	1	SCMPLT	D160	REHACB	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/06/2013	HERRT
10023552		10/17/2013	CM	SINK HOLE-327 CASIMER-DYE TEST NEGATIVE	1	SCMPLT	D160	REHACB	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/06/2013	HERRT
10023554		10/18/2013	CM	SSO CALLED IN-EMPIRE DR	1	SCMPLT	D160	REHACB	Thomas N Herr Jr	E-S-N01-C	KASZUBOM		11/06/2013	HERRT
10023605		10/22/2013	CM	SUMP PUMP CONSTANTLY RUNNING-23 ORCHARD	1	SCMPLT	D160	MURRAYK	Timothy S Gannon	E-S-N01-C	KASZUBOM		11/07/2013	ABSOLOMG
10023517	4021903	10/15/2013	CM	BACKUP-20 GARFIELD-FLUSHED/RELIEVED	1	SCMPLT	D160	REHACB	Thomas N Herr Jr	E-S-N01-C-001-SL	KASZUBOM	495	11/06/2013	HERRT
10023604	4021895	10/23/2013	CM	BACKUP-133 LOSSON RD-FLUSHED/RELIEVED	1	SCMPLT	D160	PINGITON	Thomas N Herr Jr	E-S-N01-C-003-SL	KASZUBOM	BB7B2	11/07/2013	ABSOLOMG
10022903	4021289	10/05/2013	CM	BACKUP-217 FRENCH LEA-FLUSHED/RELIEVED	1	SCMPLT	D160	JAMESI	Timothy S Gannon	E-S-N01-C-007-SL	KASZUBOM	BBFC2	11/14/2013	HERRT

NR COMPLAINTS - DISTRICT 4

10022917		10/08/2013	CM	BACKUP-88 NORTHWOOD-REFERRED TO OTHERS	1	SCMPLT	D160	REHACB	Thomas N Herr Jr	E-S-N04-C	KASZUBOM		10/22/2013	SALAHM
10023553		10/17/2013	CM	SIDEWALK CAVING IN-1276 PENORA	1	SCMPLT	D160	REHACB	Thomas N Herr Jr	E-S-N04-C	KASZUBOM		11/06/2013	HERRT
10023630		10/24/2013	CM	SIDEWALK CRACKED-2 TRENTWOOD TRL	1	SCMPLT	D160	MURRAYK	Timothy S Gannon	E-S-N04-C	KASZUBOM		11/07/2013	ABSOLOMG
10022910	4021290	10/07/2013	CM	BACKUP-257 SENECA PL-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	KWIATEKP	Timothy S Gannon	E-S-N04-C-005-SL	KASZUBOM	F29D7	10/23/2013	ZYNDAK
10022919	4021292	10/07/2013	CM	BACKUP-257 SENECA PL-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	KWIATEKP	Timothy S Gannon	E-S-N04-C-005-SL	KASZUBOM	F29D7	11/14/2013	HERRT

NR COMPLAINTS - DISTRICT 5

10022879		10/04/2013	CM	EMERG UFPO-9290 TRANSIT RD	1	SCMPLT	D190	JAMESI	Joseph T Balcarczyk	E-S-N05-C	KASZUBOM		10/21/2013	ABSOLOMG

October 2013 Maintenance

District 1

Borden
Replaced station bypass fittings with Bauer-style quick disconnects.

Cayuga
Completed installation and setup of replacement VFD #1.
Began replacement of ORF valve operators.

Clinton
Replaced station bypass fittings with Bauer-style quick disconnects.

Industrial Park
Removed debris from pumps 2,3 and 5.

Mineral Springs
Pumped ground water from meter pit.

Union
Replaced station bypass fittings with Bauer-style quick disconnects.

District 4

Aurora North
Replaced station bypass fittings with Bauer-style quick disconnects.

Aurora South
Replaced station bypass fittings with Bauer-style quick disconnects.

Bowmansville
Replaced station bypass fittings with Bauer-style quick disconnects.
Removed blockages from pump 2 on two occasions.
Removed blockage from pump 1.
Repaired mortar on station brickwork.

Forestream
Replaced station bypass fittings with Bauer-style quick disconnects.

Hall
Replaced station bypass fittings with Bauer-style quick disconnects.
Replaced impeller & cutter on pump 2.
Repaired broken pump discharge piping.

Haskell
Replaced station bypass fittings with Bauer-style quick disconnects.

Iroquois
Removed manlift motor for replacement.

Pleasantview
Replaced station bypass fittings with Bauer-style quick disconnects.

Warner
Replaced station bypass fittings with Bauer-style quick disconnects.
Began upgrade of control PLC and interface.
Repaired fuel leak on generator engine.

Zoeller
Replaced station bypass fittings with Bauer-style quick disconnects.
Removed Comminutor for rebuild.

District 5

Bryant
Replaced station bypass fittings with Bauer-style quick disconnects.
Pulled and inspected pump 1.

Clarence Research
Vacuumed debris from EQ tank.

Eastern Hills
Replaced station bypass fittings with Bauer-style quick disconnects.

Forestview
Replaced station bypass fittings with Bauer-style quick disconnects.

Loch Lea
Replaced station bypass fittings with Bauer-style quick disconnects.

Pine Breeze
Replaced station bypass fittings with Bauer-style quick disconnects.

Stahley
Replaced station bypass fittings with Bauer-style quick disconnects.

Transit Valley
Replaced station bypass fittings with Bauer-style quick disconnects.

General Maintenance

All stations were inspected weekly.
Lawn and landscape maintenance was performed at all facilities as needed.
Winterizing of facilities and generators was started.

2013 October UFPO Numbers
(By District/Region)

Total UFPO Tickets:	1486
Tickets Outside ECSD Boundary	277

		APR Code			
	Total Tickets	10 - All Clear	30 - Staked Out	Total %	Stakeout %
District 1	194	149	42	13%	9%
District 4	152	80	68	10%	15%
District 5	124	73	51	8%	11%
Total NR	470	302	161	32%	35%
District 3	446	279	155	30%	34%
District 6	91	53	34	6%	7%
District 8	65	32	32	4%	7%
Total CR	602	364	221	41%	48%
District 2	137	60	77	9%	17%
Total SR	137	60	77	9%	17%
Totals:	1209	726	459		

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
NOVEMBER 2013 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection	7	5	2
Grinder			
TOTALS	7	5	2
	14		

UFPO's	D1	D4	D5
Responses	117	123	116
Stakeouts	43	43	31
TOTAL STAKEOUTS	117		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	13,293	23,306	1,237	37,836

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	4,736	40		4,776
By District				0

	D1	D4	D5	TOTALS
House Inspections	45		5	50
Reinspections	19			19
Violations	22		1	23
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	8	8	8	24

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control	15,390			15,390
Mechanical Root Cut	202			202
Mechanically Cleaned				0

Sewerline Repairs	PIPE PATCHES - 27 SOUTH VIEW, 1291 INDIAN CHURCH
	SEWER LINE REPAIR - 1171 UNION RD.
Misc. Items	

CONSTRUCTION		
Mainline	Subdivisions	Commercial
CREEKSIDE @ PLEASANT MEADOWS		UPSTATE REBAR-PUNCHLIST
WATERFORD CAMPUS		4534 CLINTON-FIELDWALK

Plans Reviewed:	
SSO's	30 & 80 French Rd., Cheektowaga

November 2013 Maintenance

District 1

Borden
Pump 2 priming valve and check valve were rebuilt

Cayuga
Started and checked heating boiler.
Removed debris from pump 1.
Performed scheduled Air-Vacuum release maintenance.
Seized hypo containment valves were freed, lubricated, and exercised.
Repaired broken flapper in check valve 1.
Lubricated pumps, shaft u-joints and pillow blocks.

Industrial Park
Performed scheduled Air-Vacuum release maintenance.
Lubricated pumps, shaft u-joints and pillow blocks.

Mineral Springs
Ground water was pumped from meter pit.

Union
Repaired radio telemetry antenna.

District 4

Aurora South
Repaired MOSCAD antenna.

Bowmansville
Pulled and removed blockage from pump 1.

Depew
Updated level control software.
Performed scheduled Air-Vacuum release maintenance.
Replaced seized SCR cooling blower in VFD 3.
Lubricated pumps, shaft u-joints and pillow blocks.

Hall
Completed repairs to bypass piping.
Replaced impellers and cutters on both pumps.
Rebuilt spare pump.
Replaced control panel circuit breakers due to age and failures.

Iroquois
Newly repaired pump 1 was re-installed and tested.

Vanderbilt
Adjusted check valve counterweights to improve performance.

Warner
Adjusted voltage monitor to reduce false tripping.

District 4 Offices/Garages
Winterized HVAC cooling tower.
Repaired and re-calibrated glycol heat injector mixing valve in HVAC system.
Checked heat pump air filters, replaced as needed.

District 5

Clarence Research
Repaired broken piping.

General Maintenance

Snowblowers, salters and plows were prepared for winter.
Performed scheduled maintenance on all domestic water heaters.
Checked all facility heating equipment for proper operation.
Godwin pump hoses were stored at Old Depew.
Plow guide stakes were installed at all facilities.
Lawn equipment was taken to Old Cayuga garage for winter storage.
Unused/unneeded equipment was taken to County Surplus.
Began replacement of backup batteries in all MOSCAD radio telemetry units.
Continued pre-testing of all facility water service RPZ backflow preventers.
All stations were inspected weekly.
Lawn and landscape maintenance was performed at all facilities as needed.

[redacted]

NR NOVEMBER 2013 COMPLAINTS - DISTRICT 1

10024436		11/14/2013	CM	BACKUP-10 GREGORY CT-H/O PROBLEM	1	SCMPLT	E-S-N01-C		12/02/2013
10023661		11/03/2013	CM	BACKUP-11 N PRINCE-H/O PROBLEM	1	SCMPLT	E-S-N01-C		11/21/2013
10024672		11/27/2013	CM	BACKUP-1291 FRENCH-H/O PROBLEM	1	SCMPLT	E-S-N01-C		12/09/2013
10024479	4022774	11/22/2013	CM	BACKUP-151 PARWOOD-FLUSHED/RELIEVED	1	SCMPLT	E-S-N01-C		12/03/2013
10024675	4022920	11/27/2013	CM	BACKUP-23 DUBONNET-FLUSHED/NO BLOCKAGE	1	SCMPLT	E-S-N01-C		12/09/2013
10023772		11/07/2013	CM	BACKUP-30 & 50 FRENCH-WEATHER RELATED	1	SCMPLT	E-S-N01-C		11/21/2013
10024671		11/30/2013	CM	BACKUP-45 PINE COURT N.-H/O PROBLEM	1	SCMPLT	E-S-N01-C		12/09/2013
10024481		11/23/2013	CM	BACKUP-54 YVETTE-H/O PROBLEM	1	SCMPLT	E-S-N01-C		12/02/2013
10024636		11/29/2013	CM	EMERGENCY UFPO-12 AUTUMNWOOD	1	SCMPLT	E-S-N01-C		12/06/2013
10023771		11/11/2013	CM	EMERGENCY UFPO-24 SAMANTHA WAY	1	SCMPLT	E-S-N01-C		11/19/2013
10024637		11/29/2013	CM	EMERGENCY UFPO-37 LOIS DR	1	SCMPLT	E-S-N01-C		12/06/2013
10023759		11/08/2013	CM	EMERGENCY UFPO-53 LOIS DR	1	SCMPLT	E-S-N01-C		11/19/2013
10024567		11/24/2013	CM	EMERGENCY UFPO-64 RONDELAY	1	SCMPLT	E-S-N01-C		12/06/2013
10023768		11/11/2013	CM	EMERGENCY UFPO-800 HARLEM	1	SCMPLT	E-S-N01-C		11/19/2013
10024470		11/18/2013	CM	RAN OVER MH COVER-UNION RD & CENTER	1	SCMPLT	E-S-N01-C		12/02/2013
10024674		11/27/2013	CM	SEWER ODOR-161 HILLPINE-H/O PROBLEM	1	SCMPLT	E-S-N01-C		12/09/2013
10023777	4022045	11/12/2013	CM	BACKUP-209 LE HAVRE-FLUSHED/RELIEVED	1	SCMPLT	E-S-N01-C-005-SL	BBD61	11/21/2013
10024471	4022776	11/18/2013	CM	BACKUP-55 PARWOOD-FLUSHED/NO BLOCKAGE	1	SCMPLT	E-S-N01-C-007-SL	BBB0F	12/03/2013

NR NOVEMBER 2013 COMPLAINTS - DISTRICT 4

10024604		11/26/2013	CM	EMERGENCY UFPO-23 PARTRIDGE WALK	1	SCMPLT	E-S-N04-C		12/06/2013
10023753		11/07/2013	CM	ODOR-5236 GENESEE-H/O PROBLEM	1	SCMPLT	E-S-N04-C		11/25/2013
10024477		11/19/2013	CM	SINKHOLE-6 FARMINGDALE	1	SCMPLT	E-S-N04-C		12/02/2013
10024602		11/22/2013	CM	STANDING WATER IN YARD-31 ALBERT	1	SCMPLT	E-S-N04-C		12/09/2013
10023778	4021954	11/13/2013	CM	BACKUP-19 PLUMB CRK-FLUSH/NO BLOCKAGE	1	SCMPLT	E-S-N04-C-010-SL	DF851	11/19/2013

NR NOVEMBER 2013 COMPLAINTS - DISTRICT 5

10023773		11/08/2013	CM	BACKUP-8388 BRIDLEWOOD-H/O PROBLEM	1	SCMPLT	E-S-N05-C		11/21/2013
10024676		11/28/2013	CM	BACKUP-9570 HARTWIG-H/O PROBLEM	1	SCMPLT	E-S-N05-C		12/09/2013
10024482		11/23/2013	CM	EMERGENCY UFPO-10825 PARK AVE	1	SCMPLT	E-S-N05-C		11/29/2013
10023774		11/12/2013	CM	EMERGENCY UFPO-BROOKSIDE DRIVE	1	SCMPLT	E-S-N05-C		11/19/2013

MH REPAIRS NOVEMBER 2013 - D1

4022090	11/12/2013	RESET MH, 3944 BROADWAY
4022027	11/12/2013	PARGED MANHOLE, 248 LE HARVE
4022028	11/12/2013	PARGED MANHOLE, 20 W ROUEN
4021950	11/07/2013	REPLACE F/C, 2200 OLD UNION RD
4022092	11/06/2013	REPLACED F/C, 2145 OLD UNION RD
4022091	11/06/2013	PARGE MH, 2262 UNION RD
4021945	11/01/2013	RAISED MANHOLE, 4783 CLINTON ST
4021946	11/04/2013	RAISED MANHOLE, 4725 CLINTON ST

MH REPAIRS NOVEMBER 2013 - D4

4022087	11/18/2013	REPLACE F/C, 3083 OLD WENDE RD
4021944	11/04/2013	MH IN SIDEWALK RAISED-27 STEINFELDT
4022065	11/15/2013	RESET F/C, 360 ERIE ST
4022121	11/19/2013	RAISED MH, 154 CEMETERY RD

MH REPAIRS NOVEMBER 2013 - D5

4022132	11/19/2013	LOCATED/EXPOSED MANHOLE,5774 FIELD BROOK
4022129	11/19/2013	LOCATED/EXPOSED MANHOLE, 8090 GREYSTONE
4021947	11/05/2013	RAISED MANHOLE, 5821 MONAGHAN LANE
4022123	11/20/2013	RAISED MH, 5420 RAINTREE
4022133	11/19/2013	RESET MANHOLE, 5363 TRANSIT RD
4021943	11/05/2013	EXPOSED MANHOLE, 4095 THORNWOOD
4021942	11/05/2013	EXPOSED MANHOLE 4245 THORNWOOD
4022062	11/21/2013	REPLACE F & C - 4910 ACADEMY - D5, MS9

SEWER REPAIRS-NOVEMBER 2013

10023808	4022066	11/22/2013	PIPE PATCH, 3' FROM DS MH, 27 SOUTH VIEW
10023805	4022061	11/20/2013	PIPE PATCH,38' FROM US MH,1291 INDIAN CH
10024491	4022069	11/25/2013	REPAIRED, 3', PVC, 1711 UNION RD

ERIE COUNTY - SEWER DISTRICTS 1,4,5
11/1/2013 TO 11/30/2013
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	1	1	2	4
Taps	6	2	0	8
Disconnect	0	0	0	0
Repair	5	3	3	11
TOTAL	**12**	**6**	**5**	**23**

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	1	1	0	2
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	6	4	2	12
Exist Residential (ER)	0	0	0	0
TOTAL	**7**	**5**	**2**	**14**

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	1	1	1	3
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	6	11	1	18
Exist Residential Issued (ER)	5	2	2	9
TOTAL	**12**	**14**	**4**	**30**

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	$ 502	$ 502	$ 2	$ 1006
Exist Commercial Fees (EC)	$ 0	$ 0	$ 0	$ 0
New Residential Fees (NR)	$ 12	$ 7897	$ 2	$ 7911
Exist Resident Fees (ER)	$ 10	$ 4	$ 4	$ 18
TOTAL	**$ 524**	**$ 8403**	**$ 8**	**$ 8935**

Date Connected	Building_S	Building_Street_Nam	Building_T	Co	Ty	SBL NO.	Permit_Type
11/4/2013 11:30	21	Blossom Wood Lane	Cheektowa	N	S	125.09-19-	Connection
11/4/2013 13:30	612	Borden Rd	Cheektowa	N	S	125.08-9-1	Connection
11/4/2013 14:30	862	Losson	Cheektowa	N	S		Connection
11/4/2013 14:30	868	Losson	Cheektowa	N	S		Connection
11/5/2013 10:00	13	Logan Lane	Lancaster	N	S	116.31-3-4	Connection
11/5/2013 14:30	5573	Privet	Clarence	N	S	57.11-2-47	Connection
11/8/2013 11:00	1331	Seneca Creek Rd	West Sene	N	S	135.08-1-1	Connection
11/14/2013 11:00	135-145	Slatebottom Dr	Lancaster	N	M	126.54-1-3	Connection
11/15/2013 10:30	4825	Clinton St	West Sene	N	S		Connection
11/20/2013 14:00	9	Prairie Lane	Lancaster	N	S	116.08-2-1	Connection
11/22/2013 11:00	31	North America Dr	West Sene	N	C	134.12-1-2	Connection
11/22/2013 14:30	4437	Walden Ave	Lancaster	N	M	95.00-4.31	Connection
11/25/2013 11:00	8148	Laurel Park Lane	Clarence	N	S	57.05-5-5.2	Connection
11/25/2013 11:45	29	Tranquility Trail	Lancaster	N	S	Cross Creel	Connection

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
DECEMBER 2013 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection		4	3
Grinder			
TOTALS	0	4	3
		7	

UFPO's	D1	D4	D5
Responses	90	98	77
Stakeouts	36	27	39
TOTAL STAKEOUTS	102		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	10,642	25,176	2,123	37,941

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	5,985	1,827		7,812
By District				0

	D1	D4	D5	TOTALS
House Inspections	3			3
Reinspections	5			5
Violations	2			2
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	4	7	0	11

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	351			351
Mechanically Cleaned	304			304

Sewerline Repairs	23 DUBONNET - 8 L.F. 8" PVC

CONSTRUCTION		
Mainline	Subdivisions	Commercial
SIEBERT RD. EXT. - TESTING		8321 MAIN ST.
WATERFORD CAMPUS		UPSTATE REBAR-PUNCHLIST
		4534 CLINTON-FIELDWALK

Plans Reviewed:	BILLY D'S LAWN CARE STORAGE

December 2013 Maintenance

District 1

Borden
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Cayuga
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Continued replacement of VFD #3.

Clinton
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Industrial Park
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Mineral Springs
Pumped out flowmeter chamber twice.

Union
Performed scheduled Comminutor mechanical/hydraulic maintenance.

District 4

Aurora North
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Repaired generator intake louvers.
Inspected manlift.

Aurora South
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Repaired Comminutor hydraulic fluid leak.

Bowmansville
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Depew
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Freed and lubricated generator exhaust louvers.
Pumped ground water from flowmeter chamber on two occasions.
Replaced VFD #3 cooling blower.

Depew ORF
Installed permanent flowmeter sensor band in ORF outfall pipe.

Haskell
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Inspected manlift.

Pleasantview
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Inspected manlift.

Vanderbilt
Pulled pumps to verify correct rotation.

Warner
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Removed debris from Pump 2.

Wehrle Commons
Repaired electrical junction box.

Zoeller
Vacuumed debris from wetwell and Comminutor chamber.
Removed Comminutor for rebuild.
Setup and maintained bypass pumping during power outage. Standby generator was abandoned during County Home closure.

District 4 Offices/Garages
Installed new flammable material storage cabinets.
Drained and flushed domestic hot water tank.

District 5

Eastern Hills

Removed pump #1 for rebuild, replaced with spare.
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Stahley
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Transit Valley
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Repaired level control system.

General Maintenance

All stations were inspected weekly.
Began annual flowmeter calibrations.
Scheduled pump check valve inspection/maintenance was performed at all pump stations.
All pumps and drivetrains were inspected and lubricated as needed.
Snow removal was performed at all facilities as needed.

ERIE COUNTY - SEWER DISTRICTS 1,4,5
12/1/2013 TO 12/31/2013
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	3	2	5
Taps	0	1	1	2
Disconnect	0	0	0	0
Repair	4	3	2	9
TOTAL	**4**	**7**	**5**	**16**

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	4	3	7
Exist Residential (ER)	0	0	0	0
TOTAL	**0**	**4**	**3**	**7**

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	1	1
Exist Commercial Issued (EC)	1	0	0	1
New Residential Issued (NR)	2	13	3	18
Exist Residential Issued (ER)	2	5	1	8
TOTAL	**5**	**18**	**5**	**28**

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	$ 0	$ 0	$ 2	$ 2
Exist Commercial Fees (EC)	$ 2	$ 0	$ 0	$ 2
New Residential Fees (NR)	$ 504	$ 4526	$ 6	$ 5036
Exist Resident Fees (ER)	$ 4	$ 10	$ 2	$ 16
TOTAL	**$ 510**	**$ 4536**	**$ 10**	**$ 5056**

Date Connected	Building_St	Building_Street_Name	Building_T	Coc	Ty	SBL NO.	Permit_Type
12/5/2013 13:45	6227	Willow Run Court	Clarence	N	S	43.16-1-13	Connection
12/5/2013 14:30	6844	Rivera	Clarence	N	S	29.18-4-10	Connection
12/9/2013 11:00	21	Jonquille Ct	Lancaster	N	S	93.20-9-23	Connection
12/11/2013 11:00	5	Silent Meadow Lane	Lancaster	N	S	126.11-4-2	Connection
12/18/2013 11:00	8811	Stahley	Clarence	N	S	43.16-1-13	Connection
12/30/2013 11:00	46	Tranquility Trail	Lancaster	N	S	94.11-2-17	Connection
12/30/2013 11:15	50	Tranquility Trail	Lancaster	N	S	94.11-2-19	Connection

2013 December UFPO Numbers
(By District/Region)

Total UFPO Tickets:	787
Tickets Outside ECSD Boundary	142

		APR Code			
	Total Tickets	10 - All Clear	30 - Staked Out	Total %	Stakeout %
District 1	90	53	36	11%	12%
District 4	98	69	27	12%	9%
District 5	77	38	39	10%	13%
Total NR	265	160	102	34%	33%
District 3	210	119	88	27%	29%
District 6	41	14	26	5%	9%
District 8	19	8	11	2%	4%
Total CR	270	141	125	34%	41%
District 2	110	31	78	14%	26%
Total SR	110	31	78	14%	26%
Totals:	645	332	305		

NR COMPLAINTS - DIST. 1 - DECEMBER 2013

10024894		12/05/2013	CM	BACKUP-75 JEFFREY-H/O PROBLEM	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N01-C	
10024897		12/07/2013	CM	EMERGENCY UFPO-131 SAINT JUDE TER	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10024913		12/08/2013	CM	EMERGENCY UFPO-7 BASSWOOD DRIVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10024912		12/08/2013	CM	EMERGENCY UFPO-74 CROYDON DRIVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10025068		12/13/2013	CM	EMERGENCY UFPO-1300 INDIAN CHURCH	1	SCMPLT	D190	Joseph T Balcarczyk	E-S-N01-C	
10025082		12/14/2013	CM	EMERGENCY UFPO-78 BURGUNDY	1	SCMPLT	D190	Glenn R Schulz	E-S-N01-C	
10025153		12/15/2013	CM	EMERGENCY UFPO-59 BRONX AVE	1	SCMPLT	D190	Glenn R Schulz	E-S-N01-C	
10025890		12/20/2013	CM	STORM SEWER-24 WEDGEWOOD	1	SCMPLT	D170	Timothy S Gannon	E-S-N01-C	
10025825		12/21/2013	CM	BACKUP-1255-1395 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025812		12/21/2013	CM	BACKUP-1255-1395 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025792		12/21/2013	CM	BACKUP-1330 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025791		12/21/2013	CM	BACKUP-1350 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025822		12/21/2013	CM	BACKUP-243 BURCH-REFERRED TO OTHERS	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025876		12/22/2013	CM	BACKUP-102 N TRANSIT HILL-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025840		12/22/2013	CM	BACKUP-11 DANIELLE-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N01-C	
10025850		12/22/2013	CM	BACKUP-149 ZURBRICK-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N01-C	
10025780		12/22/2013	CM	BACKUP-162 AUTUMNWOOD-H/O PROBLEM	1	SCMPLT	D160	Glenn R Schulz	E-S-N01-C	
10025859		12/22/2013	CM	BACKUP-25 BARRYMORE-REFERRED TO OTHERS	1	SCMPLT	D160	Michael F Obstarczyk	E-S-N01-C	
10025872		12/22/2013	CM	BACKUP-448 CASIMER-REFERRED TO OTHERS	1	SCMPLT	D160	Paul B Kwiatek	E-S-N01-C	
10025858		12/22/2013	CM	BACKUP-59 PRESTON-REFERRED TO OTHERS	1	SCMPLT	D160	Paul J Sawicki	E-S-N01-C	
10025894		12/23/2013	CM	BACKUP-62 WOODBINE-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025900		12/25/2013	CM	EMERGENCY UFPO-51 N AMERICA DRIVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10025901		12/25/2013	CM	EMERGENCY UFPO-674 CINDY LN	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10025947		12/29/2013	CM	BACKUP-3120 TRANSIT-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025948		12/29/2013	CM	EMERGENCY UFPO-499 MINERAL SPRINGS RD	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025946		12/29/2013	CM	EMERGENCY UFPO-642 BORDEN	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10024774	4023010	12/02/2013	CM	BACKUP-114 FAIRELM-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N01-C-001-SL	BB48D
10024921	4023293	12/10/2013	CM	BACKUP-102 JANE DR-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Anthony R Notaro	E-S-N01-C-001-SL	BB40C
10025940	4024026	12/23/2013	CM	BACKUP-64 ROWLEY HLW-FLUSHED/NO BLOCK	1	SCMPLT	D160	Norman H Moorhouse	E-S-N01-C-001-SL	BB552
10025166	4023305	12/16/2013	CM	BACKUP-197 DUBONNET-FLUSHED/RELIEVED	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-004-SL	BB9B5
10024930	4023195	12/10/2013	CM	BACKUP-70 GARDEN VILL.-FLUSHED/RELIEVED	1	SCMPLT	D160	Anthony R Notaro	E-S-N01-C-006-SL	BBC2C
10024937	4023294	12/12/2013	CM	BACKUP-41 JOHN BRIAN-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Norman H Moorhouse	E-S-N01-C-007-SL	BBE6F
10025984	4024196	12/30/2013	CM	BACKUP-157 SHARON-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-009-SL	BBFFF
10024839	4023181	12/03/2013	CM	BACKUP-530 SENECA CRK-FLUSHED/NO BLOCK	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-010-SL	BC2F1
10024915	4023183	12/05/2013	CM	BACKUP-26 BRIAN LN-FLUSHED/RELIEVED	1	SCMPLT	D160	Norman H Moorhouse	E-S-N01-C-010-SL	BC1A5
10025813	4023359	12/21/2013	CM	BACKUP-716 CINDY LN-FLUSHED/RELIEVED	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-010-SL	BC310

NR COMPLAINTS - DIST. 4 - DECEMBER 2013

10024893		12/05/2013	CM	BACKUP-28 RONALD-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10024914	4023182	12/05/2013	CM	MANHOLE FULL-26 TAFT	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10024931		12/11/2013	CM	BACKUP-12 PINETREE-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025154		12/15/2013	CM	BACKUP-3 PETERBROOK CR-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025137		12/16/2013	CM	BACKUP-26 TAFT-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Anthony R Notaro	E-S-N04-C	
10025167		12/16/2013	CM	ODOR-5 AMERICO-NOT SANITARY RELATED	1	SCMPLT	D160	Norman H Moorhouse	E-S-N04-C	
10025138		12/19/2013	CM	BACKUP-26 TAFT-H/O PROBLEM	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N04-C	
10025139		12/19/2013	CM	BACKUP-38 PARKDALE-H/O PROBLEM	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025797		12/21/2013	CM	BACKUP-5 CHARLTON-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025810		12/21/2013	CM	BACKUP-6 CHARLTON-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025811		12/21/2013	CM	BACKUP-8310 WEST POINT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025781		12/21/2013	CM	EMERGENCY UFPO-105 LITCHFIELD AVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N04-C	
10025879		12/22/2013	CM	BACKUP-13 TRENTWOOD TRL-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025853		12/22/2013	CM	BACKUP-275 BROEZEL-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025788		12/22/2013	CM	BACKUP-29 TAFT-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025882		12/22/2013	CM	BACKUP-3 TRENTWOOD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025871		12/22/2013	CM	BACKUP-555 AURORA ST-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025874		12/22/2013	CM	BACKUP-6461 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025779		12/22/2013	CM	BACKUP-6461 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025778		12/22/2013	CM	BACKUP-73 REMWOOD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025877		12/22/2013	CM	BACKUP-90 IMPALA-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025941		12/23/2013	CM	BACKUP-3 TRENTWOOD-DUE TO WEATHER	1	SCMPLT	D160	John Bartoloa	E-S-N04-C	
10025938		12/23/2013	CM	BACKUP-3 TRENTWOOD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025983		12/30/2013	CM	BACKUP-26 TAFT-H/O PROBLEM	1	SCMPLT	D160	Paul Faragiano	E-S-N04-C	
10025985		12/31/2013	CM	BACKUP-14 GRAFTON-H/O PROBLEM	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025164	4023306	12/12/2013	CM	BACKUP-6461 TRANSIT-FLUSHED/RELIEVED	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N04-C-001-SL	DF663
10025951	4024146	12/28/2013	CM	ROAD CAVING-160 PLEASANT VIEW	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C-003-SL	DF706
10025136	4023308	12/16/2013	CM	MANHOLE COVER UPSIDE DOWN-9 CHARLTON	1	SCMPLT	D160	Anthony R Notaro	E-S-N04-C-005-MH	EAC36
10025982	4023974	12/23/2013	CM	BACKUP-3 TRENTWOOD-FLUSHED/RELIEVED	1	SCMPLT	D160	John Bartoloa	E-S-N04-C-006-SL	DF7B1
10025134	4023307	12/11/2013	CM	MANHOLE HIT BY PLOW-16 GLENDALE	1	SCMPLT	D160	Norman H Moorhouse	E-S-N04-C-010-MH	EA835

NR COMPLAINTS - DIST. 5 - DECEMBER 2013

10024891		12/03/2013	CM	BACKUP-8095 ROSEVILLE-H/O PROBLEM	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N05-C	
10024911		12/07/2013	CM	EMERGENCY UFPO-5120 BROOKHAVEN	1	SCMPLT	D190	Timothy S Gannon	E-S-N05-C	
10025163		12/13/2013	CM	EMERGENCY UFPO-ROLL RD AT 5571 PINE LOCH	1	SCMPLT	D190	Joseph T Balcarczyk	E-S-N05-C	
10025155		12/16/2013	CM	EMERGENCY UFPO-5210 BROOKHAVEN DR	1	SCMPLT	D190	Glenn R Schulz	E-S-N05-C	
10025815		12/21/2013	CM	BACKUP-8180 CLARENCE CTR-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025824		12/21/2013	CM	BACKUP-9332 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025789		12/22/2013	CM	BACKUP-378 COTTONWOOD-REFERRED TO OTHERS	1	SCMPLT	D160	Paul J Sawicki	E-S-N05-C	
10025878		12/22/2013	CM	BACKUP-6151 CLARENCE LN N.-DUE TO WEATHE	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025892		12/22/2013	CM	BACKUP-8045 MILES RD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025870		12/22/2013	CM	BACKUP-8060 ROSEVILLE-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N05-C	
10025891		12/22/2013	CM	BACKUP-8131 LEAH CT-STORM SEWER RELATED	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025881		12/22/2013	CM	BACKUP-8319 CLARENCE CTR-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025880		12/22/2013	CM	BACKUP-8321 WEST POINT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025942		12/23/2013	CM	BACKUP-9480 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Paul Faragiano	E-S-N05-C	
10025896		12/24/2013	CM	BACKUP-10580 MAIN-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025939	4024025	12/23/2013	CM	BACKUP-8060 ROSEVILLE-FLUSHED/NO BLOCK	1	SCMPLT	D160	Paul Faragiano	E-S-N05-C-005-SL	C11D5

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
DECEMBER 2013 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection		4	3
Grinder			
TOTALS	0	4	3
		7	

UFPO's	D1	D4	D5
Responses	90	98	77
Stakeouts	36	27	39
TOTAL STAKEOUTS	102		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	10,642	25,176	2,123	37,941

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	5,985	1,827		7,812
By District				0

	D1	D4	D5	TOTALS
House Inspections	3			3
Reinspections	5			5
Violations	2			2
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
				0

Manhole Repairs	D1	D4	D5	TOTAL
	4	7	0	11

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	351			351
Mechanically Cleaned	304			304

Sewerline Repairs	23 DUBONNET - 8 L.F. 8" PVC

CONSTRUCTION		
Mainline	Subdivisions	Commercial
SIEBERT RD. EXT. - TESTING		8321 MAIN ST.
WATERFORD CAMPUS		UPSTATE REBAR-PUNCHLIST
		4534 CLINTON-FIELDWALK

Plans Reviewed:	BILLY D'S LAWN CARE STORAGE

December 2013 Maintenance

District 1

Borden
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Cayuga
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Continued replacement of VFD #3.

Clinton
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Industrial Park
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Mineral Springs
Pumped out flowmeter chamber twice.

Union
Performed scheduled Comminutor mechanical/hydraulic maintenance.

District 4

Aurora North
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Repaired generator intake louvers.
Inspected manlift.

Aurora South
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Repaired Comminutor hydraulic fluid leak.

Bowmansville
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Depew
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Freed and lubricated generator exhaust louvers.
Pumped ground water from flowmeter chamber on two occasions.
Replaced VFD #3 cooling blower.

Depew ORF
Installed permanent flowmeter sensor band in ORF outfall pipe.

Haskell
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Inspected manlift.

Pleasantview
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Inspected manlift.

Vanderbilt
Pulled pumps to verify correct rotation.

Warner
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Removed debris from Pump 2.

Wehrle Commons
Repaired electrical junction box.

Zoeller
Vacuumed debris from wetwell and Comminutor chamber.
Removed Comminutor for rebuild.
Setup and maintained bypass pumping during power outage. Standby generator was abandoned during County Home closure.

District 4 Offices/Garages
Installed new flammable material storage cabinets.
Drained and flushed domestic hot water tank.

District 5

Eastern Hills

Removed pump #1 for rebuild, replaced with spare.
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Stahley
Performed scheduled Comminutor mechanical/hydraulic maintenance.

Transit Valley
Performed scheduled Comminutor mechanical/hydraulic maintenance.
Repaired level control system.

General Maintenance

All stations were inspected weekly.
Began annual flowmeter calibrations.
Scheduled pump check valve inspection/maintenance was performed at all pump stations.
All pumps and drivetrains were inspected and lubricated as needed.
Snow removal was performed at all facilities as needed.

ERIE COUNTY - SEWER DISTRICTS 1,4,5
12/1/2013 TO 12/31/2013
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	3	2	5
Taps	0	1	1	2
Disconnect	0	0	0	0
Repair	4	3	2	9
TOTAL	**4**	**7**	**5**	**16**

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	4	3	7
Exist Residential (ER)	0	0	0	0
TOTAL	**0**	**4**	**3**	**7**

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	1	1
Exist Commercial Issued (EC)	1	0	0	1
New Residential Issued (NR)	2	13	3	18
Exist Residential Issued (ER)	2	5	1	8
TOTAL	**5**	**18**	**5**	**28**

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	$ 0	$ 0	$ 2	$ 2
Exist Commercial Fees (EC)	$ 2	$ 0	$ 0	$ 2
New Residential Fees (NR)	$ 504	$ 4526	$ 6	$ 5036
Exist Resident Fees (ER)	$ 4	$ 10	$ 2	$ 16
TOTAL	**$ 510**	**$ 4536**	**$ 10**	**$ 5056**

Date Connected	Building_St	Building_Street_Name	Building_T	Coc	Ty	SBL NO.	Permit_Type
12/5/2013 13:45	6227	Willow Run Court	Clarence	N	S	43.16-1-13	Connection
12/5/2013 14:30	6844	Rivera	Clarence	N	S	29.18-4-10	Connection
12/9/2013 11:00	21	Jonquille Ct	Lancaster	N	S	93.20-9-23	Connection
12/11/2013 11:00	5	Silent Meadow Lane	Lancaster	N	S	126.11-4-2	Connection
12/18/2013 11:00	8811	Stahley	Clarence	N	S	43.16-1-13	Connection
12/30/2013 11:00	46	Tranquility Trail	Lancaster	N	S	94.11-2-17	Connection
12/30/2013 11:15	50	Tranquility Trail	Lancaster	N	S	94.11-2-19	Connection

2013 December UFPO Numbers
(By District/Region)

Total UFPO Tickets:	787
Tickets Outside ECSD Boundary	142

		APR Code			
	Total Tickets	10 - All Clear	30 - Staked Out	Total %	Stakeout %
District 1	90	53	36	11%	12%
District 4	98	69	27	12%	9%
District 5	77	38	39	10%	13%
Total NR	265	160	102	34%	33%
District 3	210	119	88	27%	29%
District 6	41	14	26	5%	9%
District 8	19	8	11	2%	4%
Total CR	270	141	125	34%	41%
District 2	110	31	78	14%	26%
Total SR	110	31	78	14%	26%
Totals:	645	332	305		

NR COMPLAINTS - DIST. 1 - DECEMBER 2013

10024894		12/05/2013	CM	BACKUP-75 JEFFREY-H/O PROBLEM	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N01-C	
10024897		12/07/2013	CM	EMERGENCY UFPO-131 SAINT JUDE TER	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10024913		12/08/2013	CM	EMERGENCY UFPO-7 BASSWOOD DRIVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10024912		12/08/2013	CM	EMERGENCY UFPO-74 CROYDON DRIVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10025068		12/13/2013	CM	EMERGENCY UFPO-1300 INDIAN CHURCH	1	SCMPLT	D190	Joseph T Balcarczyk	E-S-N01-C	
10025082		12/14/2013	CM	EMERGENCY UFPO-78 BURGUNDY	1	SCMPLT	D190	Glenn R Schulz	E-S-N01-C	
10025153		12/15/2013	CM	EMERGENCY UFPO-59 BRONX AVE	1	SCMPLT	D190	Glenn R Schulz	E-S-N01-C	
10025890		12/20/2013	CM	STORM SEWER-24 WEDGEWOOD	1	SCMPLT	D170	Timothy S Gannon	E-S-N01-C	
10025825		12/21/2013	CM	BACKUP-1255-1395 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025812		12/21/2013	CM	BACKUP-1255-1395 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025792		12/21/2013	CM	BACKUP-1330 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025791		12/21/2013	CM	BACKUP-1350 FRENCH-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025822		12/21/2013	CM	BACKUP-243 BURCH-REFERRED TO OTHERS	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025876		12/22/2013	CM	BACKUP-102 N TRANSIT HILL-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025840		12/22/2013	CM	BACKUP-11 DANIELLE-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N01-C	
10025850		12/22/2013	CM	BACKUP-149 ZURBRICK-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N01-C	
10025780		12/22/2013	CM	BACKUP-162 AUTUMNWOOD-H/O PROBLEM	1	SCMPLT	D160	Glenn R Schulz	E-S-N01-C	
10025859		12/22/2013	CM	BACKUP-25 BARRYMORE-REFERRED TO OTHERS	1	SCMPLT	D160	Michael F Obstarczyk	E-S-N01-C	
10025872		12/22/2013	CM	BACKUP-448 CASIMER-REFERRED TO OTHERS	1	SCMPLT	D160	Paul B Kwiatek	E-S-N01-C	
10025858		12/22/2013	CM	BACKUP-59 PRESTON-REFERRED TO OTHERS	1	SCMPLT	D160	Paul J Sawicki	E-S-N01-C	
10025894		12/23/2013	CM	BACKUP-62 WOODBINE-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025900		12/25/2013	CM	EMERGENCY UFPO-51 N AMERICA DRIVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10025901		12/25/2013	CM	EMERGENCY UFPO-674 CINDY LN	1	SCMPLT	D190	Timothy S Gannon	E-S-N01-C	
10025947		12/29/2013	CM	BACKUP-3120 TRANSIT-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025948		12/29/2013	CM	EMERGENCY UFPO-499 MINERAL SPRINGS RD	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10025946		12/29/2013	CM	EMERGENCY UFPO-642 BORDEN	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C	
10024774	4023010	12/02/2013	CM	BACKUP-114 FAIRELM-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N01-C-001-SL	BB48D
10024921	4023293	12/10/2013	CM	BACKUP-102 JANE DR-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Anthony R Notaro	E-S-N01-C-001-SL	BB40C
10025940	4024026	12/23/2013	CM	BACKUP-64 ROWLEY HLW-FLUSHED/NO BLOCK	1	SCMPLT	D160	Norman H Moorhouse	E-S-N01-C-001-SL	BB552
10025166	4023305	12/16/2013	CM	BACKUP-197 DUBONNET-FLUSHED/RELIEVED	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-004-SL	BB9B5
10024930	4023195	12/10/2013	CM	BACKUP-70 GARDEN VILL.-FLUSHED/RELIEVED	1	SCMPLT	D160	Anthony R Notaro	E-S-N01-C-006-SL	BBC2C
10024937	4023294	12/12/2013	CM	BACKUP-41 JOHN BRIAN-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Norman H Moorhouse	E-S-N01-C-007-SL	BBE6F
10025984	4024196	12/30/2013	CM	BACKUP-157 SHARON-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-009-SL	BBFFF
10024839	4023181	12/03/2013	CM	BACKUP-530 SENECA CRK-FLUSHED/NO BLOCK	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-010-SL	BC2F1
10024915	4023183	12/05/2013	CM	BACKUP-26 BRIAN LN-FLUSHED/RELIEVED	1	SCMPLT	D160	Norman H Moorhouse	E-S-N01-C-010-SL	BC1A5
10025813	4023359	12/21/2013	CM	BACKUP-716 CINDY LN-FLUSHED/RELIEVED	1	SCMPLT	D160	Timothy S Gannon	E-S-N01-C-010-SL	BC310

NR COMPLAINTS - DIST. 4 - DECEMBER 2013

10024893		12/05/2013	CM	BACKUP-28 RONALD-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10024914	4023182	12/05/2013	CM	MANHOLE FULL-26 TAFT	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10024931		12/11/2013	CM	BACKUP-12 PINETREE-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025154		12/15/2013	CM	BACKUP-3 PETERBROOK CR-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025137		12/16/2013	CM	BACKUP-26 TAFT-FLUSHED/NO BLOCKAGE	1	SCMPLT	D160	Anthony R Notaro	E-S-N04-C	
10025167		12/16/2013	CM	ODOR-5 AMERICO-NOT SANITARY RELATED	1	SCMPLT	D160	Norman H Moorhouse	E-S-N04-C	
10025138		12/19/2013	CM	BACKUP-26 TAFT-H/O PROBLEM	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N04-C	
10025139		12/19/2013	CM	BACKUP-38 PARKDALE-H/O PROBLEM	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025797		12/21/2013	CM	BACKUP-5 CHARLTON-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025810		12/21/2013	CM	BACKUP-6 CHARLTON-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025811		12/21/2013	CM	BACKUP-8310 WEST POINT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025781		12/21/2013	CM	EMERGENCY UFPO-105 LITCHFIELD AVE	1	SCMPLT	D190	Timothy S Gannon	E-S-N04-C	
10025879		12/22/2013	CM	BACKUP-13 TRENTWOOD TRL-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025853		12/22/2013	CM	BACKUP-275 BROEZEL-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025788		12/22/2013	CM	BACKUP-29 TAFT-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025882		12/22/2013	CM	BACKUP-3 TRENTWOOD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025871		12/22/2013	CM	BACKUP-555 AURORA ST-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025874		12/22/2013	CM	BACKUP-6461 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025779		12/22/2013	CM	BACKUP-6461 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025778		12/22/2013	CM	BACKUP-73 REMWOOD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025877		12/22/2013	CM	BACKUP-90 IMPALA-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025941		12/23/2013	CM	BACKUP-3 TRENTWOOD-DUE TO WEATHER	1	SCMPLT	D160	John Bartoloa	E-S-N04-C	
10025938		12/23/2013	CM	BACKUP-3 TRENTWOOD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C	
10025983		12/30/2013	CM	BACKUP-26 TAFT-H/O PROBLEM	1	SCMPLT	D160	Paul Faragiano	E-S-N04-C	
10025985		12/31/2013	CM	BACKUP-14 GRAFTON-H/O PROBLEM	1	SCMPLT	D160	Glenn R Schulz	E-S-N04-C	
10025164	4023306	12/12/2013	CM	BACKUP-6461 TRANSIT-FLUSHED/RELIEVED	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N04-C-001-SL	DF663
10025951	4024146	12/28/2013	CM	ROAD CAVING-160 PLEASANT VIEW	1	SCMPLT	D160	Timothy S Gannon	E-S-N04-C-003-SL	DF706
10025136	4023308	12/16/2013	CM	MANHOLE COVER UPSIDE DOWN-9 CHARLTON	1	SCMPLT	D160	Anthony R Notaro	E-S-N04-C-005-MH	EAC36
10025982	4023974	12/23/2013	CM	BACKUP-3 TRENTWOOD-FLUSHED/RELIEVED	1	SCMPLT	D160	John Bartoloa	E-S-N04-C-006-SL	DF7B1
10025134	4023307	12/11/2013	CM	MANHOLE HIT BY PLOW-16 GLENDALE	1	SCMPLT	D160	Norman H Moorhouse	E-S-N04-C-010-MH	EA835

NR COMPLAINTS - DIST. 5 - DECEMBER 2013

10024891		12/03/2013	CM	BACKUP-8095 ROSEVILLE-H/O PROBLEM	1	SCMPLT	D160	Thomas N Herr Jr	E-S-N05-C	
10024911		12/07/2013	CM	EMERGENCY UFPO-5120 BROOKHAVEN	1	SCMPLT	D190	Timothy S Gannon	E-S-N05-C	
10025163		12/13/2013	CM	EMERGENCY UFPO-ROLL RD AT 5571 PINE LOCH	1	SCMPLT	D190	Joseph T Balcarczyk	E-S-N05-C	
10025155		12/16/2013	CM	EMERGENCY UFPO-5210 BROOKHAVEN DR	1	SCMPLT	D190	Glenn R Schulz	E-S-N05-C	
10025815		12/21/2013	CM	BACKUP-8180 CLARENCE CTR-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025824		12/21/2013	CM	BACKUP-9332 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025789		12/22/2013	CM	BACKUP-378 COTTONWOOD-REFERRED TO OTHERS	1	SCMPLT	D160	Paul J Sawicki	E-S-N05-C	
10025878		12/22/2013	CM	BACKUP-6151 CLARENCE LN N.-DUE TO WEATHE	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025892		12/22/2013	CM	BACKUP-8045 MILES RD-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025870		12/22/2013	CM	BACKUP-8060 ROSEVILLE-DUE TO WEATHER	1	SCMPLT	D160	Glenn R Schulz	E-S-N05-C	
10025891		12/22/2013	CM	BACKUP-8131 LEAH CT-STORM SEWER RELATED	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025881		12/22/2013	CM	BACKUP-8319 CLARENCE CTR-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025880		12/22/2013	CM	BACKUP-8321 WEST POINT-DUE TO WEATHER	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025942		12/23/2013	CM	BACKUP-9480 TRANSIT-DUE TO WEATHER	1	SCMPLT	D160	Paul Faragiano	E-S-N05-C	
10025896		12/24/2013	CM	BACKUP-10580 MAIN-H/O PROBLEM	1	SCMPLT	D160	Timothy S Gannon	E-S-N05-C	
10025939	4024025	12/23/2013	CM	BACKUP-8060 ROSEVILLE-FLUSHED/NO BLOCK	1	SCMPLT	D160	Paul Faragiano	E-S-N05-C-005-SL	C11D5