



# COUNTY OF ERIE

**MARK C. POLONCARZ**

COUNTY EXECUTIVE  
DEPARTMENT OF ENVIRONMENT & PLANNING

THOMAS J. DEARING  
COMMISSIONER

JOSEPH L. FIEGL, P.E.  
DEPUTY COMMISSIONER

December 18, 2015

Keith Gregor  
Diane Gregor  
3270 Clinton St  
West Seneca, NY 14224

Re: 1<sup>ST</sup> VIOLATION NOTICE  
Erie County Sewer District (ECSD) No. 1, Mini System 9  
For Property Located at: **3270 Clinton St, Gregor's Garden Grove**

Dear Property Owner:

A recent review of our records indicate that the above mentioned property was dye tested on 12/14/2015 and the following violation of Section 501, Paragraph K of the Rules and Regulations for Erie County Sewer Districts was observed:

**STORM SEWER DRAINAGE INTAKE (DI) IS CONNECTED TO THE  
SANITARY SEWER**

Per the Rules and Regulations for Erie County Sewer Districts, Article XI Section 1101, correction of the violation shall be made within 20 days upon receipt of such violation:

**PERMANENTLY DISCONNECT ALL STORM SEWERS FROM THE  
SANITARY SEWER.**

Surface runoff, ground water, roof runoff, subsurface drainage, or cooling water shall NOT be discharged into the sanitary sewer system. Roof drains or sump pumps must be disconnected from the sanitary sewer. They may be connected into a storm sewer, if one is available. Permits and inspection may be required for a direct connection to the storm sewer. Please contact your local municipality for further information, as the Sewer District does not control storm sewers in your area. If you have any questions regarding the dye test please contact us at (716) 684-1235.

-Continued-

*Item  
5(b)*


**Violation Notice**

Page 2

Your property will be reinspected upon request. Appointments for reinspection can be made by calling (716) 684-1235.

If the violation does not get corrected, the Board of Managers will request a hearing to be held to obtain compliance, with the possibility of a fine being levied against the property.

Very truly yours,



Richard J Rehac  
Sewer District Manager


**SECTION 305 – Footing Drains, Roof Drains and Sump Pumps:**

***"Footing drains, roof drains, sump pumps, or other drains discharging surface or ground water shall not be connected to the sanitary sewer."***

**SECTION 501 – Prohibited Discharges:**

***"The following substances and Wastewaters are specifically prohibited from discharge to the District Sewerage System: k. Surface runoff, ground water, roof runoff, sump pump discharge, subsurface drainage, or cooling water."***

The Rules and Regulations for Erie County Sewer Districts can be viewed at [www.erie.gov/dsm-R&R](http://www.erie.gov/dsm-R&R)



# 3270 Clinton St, West Seneca

Erie County Sewer District No. 1 (ECS&D 1)

Violation Found Dye Testing 12/14/2015:

**STORM SEWER DRAINAGE INTAKE (DI) IS CONNECTED TO THE SANITARY SEWER**

**Correction:**

**PERMANENTLY DISCONNECT ALL STORM SEWERS FROM THE SANITARY SEWER**

