

## District 5 BOM Update:

- **Pretreatment**

- **FOG Program**

Pretreatment staff followed up on a March 2014 grease blockage near the Bryant & Stratton Pump Station in Clarence. Crews responding to a complaint found a blockage of grease, stones and shop rags. Staff visited all of the auto service centers/car dealers located across the street from the blockage. 3 of the 5 auto dealers were in need of having their separator cleaned. Staff will also review footage from sewer line televising to assist in determining source or direction. Follow-up letters will be sent.

*Item  
6(c)*