

New York State Fire Mobilization and Mutual Aid

Storm Emergency Fire Unit Specifications

- **2 firefighters with personal protective equipment & SCBA with spare cylinders**
- **4 wheel drive pickup or similar size vehicle (should be fire department owned)**
- **Portable pump**
- **Hard suction w/ strainer**
- **200' of discharge hose**
- **necessary fittings, adapters, etc.**
- **Portable generator**
- **Electric adapters to adapt to household type receptacles**
- **Portable lighting for night operations**
- **fuel can for pump and generator**
- **Chain saw**
- **fuel and oil for chain saw**
- **two shovels**
- **Carbon Monoxide Detector**
- **2 ½ gallon Pressurized Water Extinguisher**
- **Minimum 10 pound CO2 or Dry Chemical Extinguisher**

NOTE: Personnel responding with a SEFU should be self sufficient for a minimum period of 24 hours. This should include food provisions and water.